

SUPER GAS FOODMART
3479 GEORGIA STREET
GARY, IN 46407
219-884-3480
MAY 8, 2025 2:08 PM
LEAK TEST REPORT
T 1:UNLEADED
PROBE SERIAL NUM 656657
TEST STARTING TIME:
JAN 24, 2007 1:51 PM
HEIGHT = 36.1 INCHES
WATER = 0.0 INCHES
TEMP = 50.2 F
TEST LENGTH = 2.0 HRS
STRT VOLUME = 4332.5 GAL
PERCENT VOLUME = 37.1
LEAK TEST RESULTS
RATE = -45.95 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

SUPER GAS FOODMART
3479 GEORGIA STREET
GARY, IN 46407
219-884-3480
MAY 8, 2025 2:08 PM
CSLD TEST RESULTS
- - - - -
MAY 8, 2025 2:08 PM
T 1:UNLEADED
PROBE SERIAL NUM 656657
0.2 GAL/HR TEST
PER: MAY 8, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 656658
0.2 GAL/HR TEST
PER: MAY 8, 2025 PASS

***** END *****

SUPER GAS FOODMART
3479 GEORGIA STREET
GARY, IN 46407
219-884-3480
MAY 8, 2025 2:08 PM
LIQUID STATUS
- - - - -
MAY 8, 2025 2:08 PM
NONE
***** END *****

SUPER GAS FOODMART
3479 GEORGIA STREET
GARY, IN 46407
219-884-3480
MAY 8, 2025 2:08 PM
LEAK TEST REPORT
T 2:PREMIUM
PROBE SERIAL NUM 656658
TEST STARTING TIME:
JAN 24, 2007 1:51 PM
HEIGHT = 21.1 INCHES
WATER = 0.0 INCHES
TEMP = 51.9 F
TEST LENGTH = 2.0 HRS
STRT VOLUME = 1351.7 GAL
PERCENT VOLUME = 17.0
LEAK TEST RESULTS
0.20 GAL/HR TEST INVL
0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR
PERCENT VOLUME TOO LOW
***** END *****