

Work Order: 415441

Status: Invoiced

Date:

6/4/2025

Location: GO LO

Bill To: GO LO

**Prince Ghotra
3479 GEORGIA STREET
GARY, IN 46409**

**3479 GEORGIA STREET
GARY, IN 46409**

Solution Notes

[Issue:] need to pull drop tubes.

On June 4, 2025, Luke attempted to remove both the premium and regular drop tubes; however, neither could be removed. The vapor adapters on both the regular and premium tanks were cut off, and both ball floats were removed. Additionally, the leak detector models on both tanks are VMI Vaporless.

Subtotal:

SC/ST:

Total: