

PRINCE
4700 BROADWAY
GARY, IN

FEB 6, 2025 4:19 PM

CSLD TEST RESULTS

FEB 6, 2025 4:19 PM

T 1:UNLEADED
PROBE SERIAL NUM 451783

0.2 GAL/HR TEST
PER: FEB 6, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 451784

0.2 GAL/HR TEST
PER: FEB 6, 2025 PASS

* * * * * END * * * * *

PRINCE
4700 BROADWAY
GARY, IN

FEB 6, 2025 4:19 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 451783

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PRINCE
4700 BROADWAY
GARY, IN

FEB 6, 2025 4:19 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 451784

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PRINCE
4700 BROADWAY
GARY, IN

FEB 6, 2025 4:19 PM

LIQUID STATUS

- - - - -
FEB 6, 2025 4:19 PM

L 1: UNLEADED
SENSOR NORMAL

L 2: PREMIUM
SENSOR NORMAL

* * * * * END * * * * *

PRINCE
4700 BROADWAY
GARY, IN

FEB 6, 2025 4:19 PM

LIQUID STATUS

- - - - -
FEB 6, 2025 4:19 PM

L 1: UNLEADED
SENSOR NORMAL

L 2: PREMIUM
SENSOR NORMAL

* * * * * END * * * * *