

PRINCE
4700 BROADWAY
GARY, IN

MAY 8, 2025 1:48 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 451783

NO TEST DATA AVAILABLE

***** END *****

PRINCE
4700 BROADWAY
GARY, IN

MAY 8, 2025 1:48 PM

CSLD TEST RESULTS

MAY 8, 2025 1:48 PM

T 1:UNLEADED
PROBE SERIAL NUM 451783

0.2 GAL/HR TEST
PER: MAY 8, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 451784

0.2 GAL/HR TEST
PER: MAY 8, 2025 PASS

***** END *****

PRINCE
4700 BROADWAY
GARY, IN

MAY 8, 2025 1:48 PM

CSLD TEST RESULTS

MAY 8, 2025 1:48 PM

T 1:UNLEADED
PROBE SERIAL NUM 451783

0.2 GAL/HR TEST
PER: MAY 8, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 451784

0.2 GAL/HR TEST
PER: MAY 8, 2025 PASS

***** END *****

PRINCE
4700 BROADWAY
GARY, IN

MAY 8, 2025 1:48 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 451784

NO TEST DATA AVAILABLE

***** END *****

PRINCE
4700 BROADWAY
GARY, IN

MAY 8, 2025 1:48 PM

LIQUID STATUS

MAY 8, 2025 1:48 PM

L 1:UNLEADED
SENSOR NORMAL

L 2:PREMIUM
SENSOR NORMAL

***** END *****

PRINCE
4700 BROADWAY
GARY, IN

MAY 8, 2025 1:48 PM

LIQUID STATUS

MAY 8, 2025 1:48 PM

L 1:UNLEADED
SENSOR NORMAL

L 2:PREMIUM
SENSOR NORMAL

***** END *****