

PRINCE
700 BROADWAY
GARY, IN

APR 9, 2025 4:30 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 451783

NO TEST DATA AVAILABLE

***** END *****

PRINCE
4700 BROADWAY
GARY, IN

APR 9, 2025 4:30 PM

CSLD TEST RESULTS

- - - - -

APR 9, 2025 4:30 PM

T 1:UNLEADED
PROBE SERIAL NUM 451783

0.2 GAL/HR TEST
PER: APR 9, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 451784

0.2 GAL/HR TEST
PER: APR 9, 2025 PASS

***** END *****

PRINCE
4700 BROADWAY
GARY, IN

APR 9, 2025 4:30 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 451784

NO TEST DATA AVAILABLE

***** END *****

PRINCE
4700 BROADWAY
GARY, IN

APR 9, 2025 4:30 PM

LIQUID STATUS

- - - - -

APR 9, 2025 4:30 PM

L 1:UNLEADED
SENSOR NORMAL

L 2:PREMIUM
SENSOR NORMAL

***** END *****