

PRINCE
4700 BROADWAY
GARY, IN

JUL 6, 2025 1:48 PM

CSLD TEST RESULTS

JUL 6, 2025 1:48 PM

T 1:UNLEADED
PROBE SERIAL NUM 451783

0.2 GAL/HR TEST
PER: JUL 6, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 451784

0.2 GAL/HR TEST
PER: JUL 6, 2025 PASS

* * * * * END * * * * *

PRINCE
4700 BROADWAY
GARY, IN

JUL 6, 2025 1:48 PM

LIQUID STATUS

JUL 6, 2025 1:48 PM

L 1:UNLEADED
SENSOR NORMAL

L 2:PREMIUM
SENSOR NORMAL

* * * * * END * * * * *