

PRINCE
4700 BROADWAY
GARY, IN

AUG 8, 2025 2:17 PM

CSLD TEST RESULTS

AUG 8, 2025 2:17 PM

T 1:UNLEADED
PROBE SERIAL NUM 451783

0.2 GAL/HR TEST
PER: AUG 8, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 451784

0.2 GAL/HR TEST
PER: AUG 8, 2025 PASS

* * * * * END * * * * *

PRINCE
4700 BROADWAY
GARY, IN

AUG 8, 2025 2:17 PM

LIQUID STATUS

AUG 8, 2025 2:17 PM

L 1:UNLEADED
SENSOR NORMAL

L 2:PREMIUM
SENSOR NORMAL

* * * * * END * * * * *