

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 11505
Address	4700 Broadway
City	Gary
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro MLLD		
Prem	Fe Petro MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	31	30	140 ml	189ml	3 sec	Pass
2	Premium	30	29	120 ml	189ml	3 sec	Pass
3					189ml	.	
4					189ml	.	
5					189ml	.	
6					189ml	.	
7					189ml	.	
8					189ml	.	

Comment:

Technician Signature :

Josh Rider