



5296 Breakers Way, Carmel, IN 46033

Date

5/6/25

LIQUID SENSOR FUNCTIONALITY TESTING

Facility Name:	Quik Mart Citgo
Address:	4700 Broadway
City, State, Zip Code:	Gary, IN 46408
Facility I.D. #:	11505

Owner:	Meet, Inc.
Address:	4700 Broadway
City, State, Zip Code:	Gary, IN 46408
Phone #:	

This procedure is to determine whether liquid sensors located in the interstitial space of UST systems are able to detect the presence of water and fuel. See PEI/RPI200 Section 8.3 for the test procedure.

Sensor Location	STP 1	STP 2						
Product Stored	Regular	Premium						
Type of Sensor	Non-Discr	Non-Discr						
Test Liquid	Water	Water						
Is the ATG console clear of any active or recurring warnings or alarms regarding the leak sensor? If the sensor is in alarm and functioning, indicate why.	Yes	Yes						
Is the sensor alarm circuit operational?	Yes	Yes						
Has sensor been inspected and in good operating condition?	Yes	Yes						
When placed in the test liquid, does the sensor trigger an alarm?	Yes	Yes						
When an alarm is triggered, is the sensor properly identified on the ATG console?	Yes	Yes						
Any "No" answers indicates the sensor fails the test.								
Test Results	Pass	Pass						

Comment

Tester's Name : Josh Rider

Tester's Signature : 