



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

5/6/25

PRODUCT LINE TEST

Test Location Information	
Name	FID 11505
Address	4700 Broadway
City	Gary
Phone	
Contact	

Technician Information	
Name	Josh Rider
Cert #	UC202406986

Applied Pressure
50 psi

#1	Product Type : Regular				
TIME	DATA	+/-	GPL	RES	GPH
11:55am	77	0	0.0037	0	0
12:10pm	76	-1	0.0037	.0037	.0148
12:25pm	76	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2	Product Type : Premium				
TIME	DATA	+/-	GPL	RES	GPH
12:35pm	74	0	0.0037	0	0
12:50pm	74	0	0.0037	0	0
1:05pm	74	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3	Product Type :				
TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4	Product Type :				
TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

PRODUCT LINE TEST

Test Location Information		Technician Information	
Name	FID 11505	Name	Josh Rider
Address	4700 Broadway	Cert #	UC202406986
City	Gary		
Phone			
Contact			

Applied Pressure
50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3		.
4		.
5		.
6		.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 