

TRIENNIAL INSPECTION

Facility Name: GARY CITGO
 Facility Address: 4700 BROADWAY GARY IN 46408
 Facility ID: 11505

Test Date: 06/26/2025

SPILL CONTAINER INTEGRITY TESTING

Product	Pul							
Test Type	Repair							
Clean of liquid/debris	YES							
VISUAL INSPECTION	PASS							
Test Start Time	1030							
Test End Time	1130							
Starting Water Level (inches)	14							
Ending Water Level (inches)	14							
Water Level Change (inches)	0							
HYDROSTATIC TEST RESULT	PASS							
Double wall								
Vacuum Test Length (minutes)								
Starting Inches of Water								
Ending Inches of Water								
VACUUM TEST RESULT								

Comments

Technician Name: Brett Zandstra

Dispatch # 7673

B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19