

ANNUAL OPERATIONAL TESTING REPORT

Facility Name: GARY CITGO Test Date: 05/06/2024

Facility Address: 4700 BROADWAY GARY IN 46408

Facility ID: 11505

ATG INSPECTION - CONTROLLER							
ATG Visual and Audible Alarm	Verify System Configuration	Test Battery Backup	Verify Positive Shutdown				
PASS	PASS	PASS	PASS				

ATG INSPECTION – PROBES							
Tank #	T1	T2					
Product	Regular	Premium					
Probe activates with a float mechanism?	PASS	PASS					
Cables are free of kinks	PASS	PASS					
Alarm Operates	PASS	PASS					
Alarm Communicates with Controller	PASS	PASS					
Floats Move Freely	PASS	PASS					
Shaft not damaged or bent	PASS	PASS					

Comments		

Technician Name: Jack Davids

Dispatch # 401827

Technician Signature:

B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19