

TEST: 2:57 PM
RESULTS: 117
2:50PM PASS
TESTS OF 24 HOURS PASSED : 117
PREV 64
SINCE MIDNIGHT : 64

0.20 GAL/HR
JUL 6.2025 3:36AM PASS
JUL 30.2025 11:46PM PASS
JUN 26.2025 8:44AM PASS
JUN 24.2025 1:09PM PASS
JUN 20.2025 3:38AM PASS
JUN 18.2025 1:16PM PASS
JUN 14.2025 5:00AM PASS
JUN 11.2025 12:44AM PASS
JUN 8.2025 3:23AM PASS

0.10 GAL/HR
JUL 6.2025 3:53AM PASS
JUL 3.2025 10:20PM PASS
JAN 3.2024 5:27AM PASS
JUL 1.2024 2:52PM PASS
DEC 31.2023 4:43AM PASS
JUN 30.2022 3:15AM PASS
DEC 28.2021 2:43AM PASS
JUN 27.2021 5:03AM PASS
DEC 25.2020 4:11AM PASS
4:40AM PASS

3.0 GAL/HR
LAST TEST: 6.2025
NUMBER OF TESTS OF 24 HOURS PASSED : 117
PREV 64
SINCE MIDNIGHT : 64

2:PREMIUM
RESULTS: 117
2:50PM PASS
TESTS OF 24 HOURS PASSED : 117
PREV 64
SINCE MIDNIGHT : 64

0.20 GAL/HR
JUL 6.2025 3:36AM PASS
JUL 30.2025 11:46PM PASS
JUN 26.2025 8:44AM PASS
JUN 24.2025 1:09PM PASS
JUN 20.2025 3:38AM PASS
JUN 18.2025 1:16PM PASS
JUN 14.2025 5:00AM PASS
JUN 11.2025 12:44AM PASS
JUN 8.2025 3:23AM PASS

0.10 GAL/HR
JUL 6.2025 3:53AM PASS
JUL 3.2025 10:20PM PASS
JAN 3.2024 5:27AM PASS
JUL 1.2024 2:52PM PASS
DEC 31.2023 4:43AM PASS
JUN 30.2022 3:15AM PASS
DEC 28.2021 2:43AM PASS
JUN 27.2021 5:03AM PASS
DEC 25.2020 4:11AM PASS
4:40AM PASS

***** END *****

PHILLIPS 66
2490 CLARK
GARY IN

JUL 6. 2025 2:57 PM
CSLD TEST RESULTS
JUL 6. 2025 2:57 PM

T 1:REGULAR
PROBE SERIAL NUM 394733
0.2 GAL/HR TEST
PER: JUL 6. 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 394734
0.2 GAL/HR TEST
PER: JUL 6. 2025 PASS

***** END *****