

PHILLIPS 66
2490 CLARK
GARY IN

JUN 10, 2025 4:35 PM

CSLD TEST RESULTS

JUN 10, 2025 4:35 PM

T 1:REGULAR
PROBE SERIAL NUM 394733

0.2 GAL/HR TEST
PER: JUN 10, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 394734

0.2 GAL/HR TEST
PER: JUN 10, 2025 PASS

* * * * * END * * * * *

PHILLIPS 66
2490 CLARK
GARY IN

JUN 10, 2025 4:35 PM

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:
JUN 10, 2025 4:24PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 140

SINCE MIDNIGHT : 87

0.20 GAL/HR RESULTS:

JUN 9, 2025 12:12AM PASS

JUN 6, 2025 1:16AM PASS

JUN 2, 2025 3:40AM PASS

MAY 29, 2025 1:37AM PASS

MAY 25, 2025 4:10AM PASS

MAY 21, 2025 1:32AM PASS

MAY 17, 2025 1:34AM PASS

MAY 13, 2025 3:45AM PASS

MAY 9, 2025 2:04AM PASS

MAY 5, 2025 3:09AM PASS

0.10 GAL/HR RESULTS:

DEC 28, 2024 6:30AM PASS

JUL 9, 2023 1:42AM PASS

JAN 2, 2023 1:32AM PASS

JUN 30, 2022 3:44AM PASS

DEC 27, 2021 12:11AM PASS

JUN 25, 2021 1:28AM PASS

DEC 21, 2020 4:17AM PASS

JUN 20, 2020 2:18AM PASS

DEC 17, 2019 3:23AM PASS

JUN 16, 2019 2:28AM PASS

Q 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
JUN 10, 2025 4:23PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 131

SINCE MIDNIGHT : 80

0.20 GAL/HR RESULTS:

JUN 8, 2025 3:23AM PASS

JUN 4, 2025 5:45PM PASS

JUN 2, 2025 2:07AM PASS

JUN 29, 2025 1:21AM PASS

MAY 25, 2025 3:55AM PASS

MAY 22, 2025 12:28AM PASS

MAY 19, 2025 5:38AM PASS

MAY 15, 2025 10:32PM PASS

MAY 13, 2025 2:17AM PASS

MAY 9, 2025 2:03AM PASS

0.10 GAL/HR RESULTS:

JAN 3, 2025 10:20PM PASS

JUL 3, 2024 5:27AM PASS

JUL 1, 2024 10:52PM PASS

JAN 3, 2023 2:43AM PASS

JUL 31, 2022 4:15AM PASS

DEC 30, 2022 3:43AM PASS

JUN 28, 2021 2:03AM PASS

DEC 27, 2021 5:11AM PASS

JUN 25, 2020 4:40AM PASS

DEC 24, 2020 1:27AM PASS

Q 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
JUN 10, 2025 4:23PM PASS

NUMBER OF TESTS PASSED 131
PREV 24 HOURS :
SINCE MIDNIGHT : 80

0.20 GAL/HR RESULTS:

JUN 8, 2025 3:23AM PASS
JUN 4, 2025 5:45PM PASS
JUN 2, 2025 2:07AM PASS
MAY 29, 2025 1:21AM PASS
MAY 25, 2025 3:55AM PASS
MAY 22, 2025 12:28AM PASS
MAY 19, 2025 5:38AM PASS
MAY 15, 2025 10:32PM PASS
MAY 13, 2025 2:17AM PASS
MAY 9, 2025 2:03AM PASS

0.10 GAL/HR RESULTS:

JAN 3, 2025 10:20PM PASS
JUL 3, 2024 5:27AM PASS
JAN 1, 2024 10:52PM PASS
JUL 3, 2023 2:43AM PASS
DEC 31, 2022 4:15AM PASS
JUN 30, 2022 3:43AM PASS
DEC 28, 2021 2:03AM PASS
JUN 27, 2021 5:11AM PASS
DEC 25, 2020 4:40AM PASS
JUN 24, 2020 1:27AM PASS

***** END *****

PHILLIPS 66
2490 CLARK
GARY IN

JUN 10, 2025 4:35 PM

LEAK TEST REPORT

T 1:REGULAR
PROBE SERIAL NUM 394736

TEST STARTING TIME:
JUN 13, 2017 12:27 AM

HEIGHT = 49.9 INCHES
WATER = 0.0 INCHES
TEMP = 71.3 F

TEST LENGTH = 2.0 HR
STRT VOLUME = 5494.0 GA
PERCENT VOLUME = 56.0

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
TEMP CHANGE TOO LARGE

***** END *****

PHILLIPS 66
2490 CLARK
GARY IN

JUN 10, 2025 4:35 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 394736

TEST STARTING TIME:
JUN 13, 2017 12:27 AM

HEIGHT = 23.0 INCHES
WATER = 0.0 INCHES
TEMP = 63.1 F

TEST LENGTH = 2.0 HR
STRT VOLUME = 1520.9 GA
PERCENT VOLUME = 19.1

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR

***** END *****