

PHILLIPS 66
2490 CLARK
GARY IN

MAY 8, 2025 3:43 PM

LEAK TEST REPORT

T 1:REGULAR
PROBE SERIAL NUM 394733

TEST STARTING TIME:
JUN 13, 2017 12:27 AM

HEIGHT = 49.9 INCHES
WATER = 0.0 INCHES
TEMP = 71.3 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 5494.0 GAL
PERCENT VOLUME = 56.0

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
TEMP CHANGE TOO LARGE

* * * * * END * * * * *

PHILLIPS 66
2490 CLARK
GARY IN

MAY 8, 2025 3:43 PM

CSLD TEST RESULTS

- - - - -
MAY 8, 2025 3:43 PM

T 1:REGULAR
PROBE SERIAL NUM 394733

0.2 GAL/HR TEST
PER: MAY 8, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 394734

0.2 GAL/HR TEST
PER: MAY 8, 2025 PASS

* * * * * END * * * * *

PHILLIPS 66
2490 CLARK
GARY IN

MAY 8, 2025 3:43 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 394734

TEST STARTING TIME:
JUN 13, 2017 12:27 AM

HEIGHT = 23.0 INCHES
WATER = 0.0 INCHES
TEMP = 63.1 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1520.9 GAL
PERCENT VOLUME = 19.1

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
LOW LEVEL TEST ERROR

* * * * * END * * * * *

PHILLIPS 66
2490 CLARK
GARY IN

MAY 8. 2025 3:43 PM

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 8.2025 3:36PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 159
SINCE MIDNIGHT : 89

0.20 GAL/HR RESULTS:

MAY	5.2025	3:09AM	PASS
MAY	1.2025	1:01AM	PASS
APR	27.2025	1:38AM	PASS
APR	22.2025	12:30AM	PASS
APR	19.2025	12:55AM	PASS
APR	15.2025	5:00AM	PASS
APR	11.2025	8:30PM	PASS
APR	7.2025	4:11AM	PASS
APR	3.2025	11:35PM	PASS
APR	1.2025	3:34AM	PASS

0.10 GAL/HR RESULTS:

DEC	28.2024	6:30AM	PASS
JUL	9.2023	1:42AM	PASS
JAN	2.2023	1:32AM	PASS
JUN	30.2022	3:44AM	PASS
DEC	27.2021	12:11AM	PASS
JUN	25.2021	1:28AM	PASS
DEC	21.2020	4:17AM	PASS
JUN	20.2020	2:18AM	PASS
DEC	17.2019	3:23AM	PASS
JUN	16.2019	2:28AM	PASS

Q 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 8.2025 3:35PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 144
SINCE MIDNIGHT : 85

0.20 GAL/HR RESULTS:

MAY	5.2025	11:11PM	PASS
MAY	3.2025	1:50AM	PASS
APR	29.2025	7:52PM	PASS
APR	25.2025	4:04PM	PASS
APR	21.2025	7:05PM	PASS
APR	19.2025	2:01AM	PASS
APR	15.2025	7:14PM	PASS
APR	13.2025	2:25AM	PASS
APR	9.2025	7:44PM	PASS
APR	5.2025	10:15PM	PASS

0.10 GAL/HR RESULTS:

JAN	3.2025	10:20PM	PASS
JUL	3.2024	5:27AM	PASS
JAN	1.2024	10:52PM	PASS
JUL	3.2023	2:43AM	PASS
DEC	31.2022	4:15AM	PASS
JUN	30.2022	3:43AM	PASS
DEC	28.2021	2:03AM	PASS
JUN	27.2021	5:11AM	PASS
DEC	25.2020	4:40AM	PASS
JUN	24.2020	1:27AM	PASS

* * * * * END * * * * *