

PHILLIPS 66
2490 CLARK
GARY IN

SEP 10, 2025 3:54 PM

COLD TEST RESULTS

SEP 10, 2025 3:54 PM

T 1:REGULAR
PROBE SERIAL NUM 394733

0.2 GAL/HR TEST
PER: SEP 10, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 394734

0.2 GAL/HR TEST
PER: SEP 10, 2025 PASS

***** END *****

PHILLIPS 66
2490 CLARK
GARY IN

SEP 10, 2025 3:54 PM

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:
SEP 10, 2025 3:51PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 149
SINCE MIDNIGHT : 98

0.20 GAL/HR RESULTS:

SEP	8, 2025	1:10AM	PASS
SEP	4, 2025	1:03AM	PASS
AUG	31, 2025	2:49AM	PASS
AUG	27, 2025	4:36AM	PASS
AUG	23, 2025	3:12AM	PASS
AUG	20, 2025	12:12AM	PASS
AUG	17, 2025	6:14AM	PASS
AUG	13, 2025	1:32AM	PASS
AUG	9, 2025	12:38AM	PASS
AUG	5, 2025	2:34AM	PASS

0.10 GAL/HR RESULTS:

JUN	30, 2025	4:36AM	PASS
DEC	28, 2024	6:30AM	PASS
JUL	9, 2023	1:42AM	PASS
JAN	2, 2023	1:32AM	PASS
JUN	30, 2022	3:44AM	PASS
DEC	27, 2021	12:11AM	PASS
JUN	25, 2021	1:28AM	PASS
DEC	21, 2020	4:17AM	PASS
JUN	20, 2020	2:18AM	PASS
DEC	17, 2019	3:23AM	PASS

Q 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
SEP 10, 2025 3:52PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 135
SINCE MIDNIGHT : 90

0.20 GAL/HR RESULTS:

SEP	8, 2025	5:29AM	PASS
SEP	5, 2025	12:24AM	PASS
SEP	2, 2025	1:50AM	PASS
AUG	29, 2025	1:40AM	PASS
AUG	25, 2025	11:35PM	PASS
AUG	23, 2025	1:27AM	PASS
AUG	19, 2025	11:42PM	PASS
AUG	17, 2025	7:23AM	PASS
AUG	13, 2025	11:29PM	PASS
AUG	11, 2025	2:13AM	PASS

0.10 GAL/HR RESULTS:

JUL	6, 2025	3:53AM	PASS
JAN	3, 2025	10:20PM	PASS
JUL	3, 2024	5:27AM	PASS
JAN	1, 2024	10:52PM	PASS
JUL	3, 2023	2:43AM	PASS
DEC	31, 2022	4:15AM	PASS
JUN	30, 2022	3:43AM	PASS
DEC	28, 2021	2:03AM	PASS
JUN	27, 2021	5:11AM	PASS
DEC	25, 2020	4:40AM	PASS

***** END *****