

PHILLIPS 66
2490 CLARK
GARY IN
AUG 8. 2025 3:32 PM
PRESSURE LINE LEAK
TEST RESULTS
Q 1:REGULAR
3.0 GAL/HR RESULTS:
LAST TEST:
AUG 8.2025 3:24PM PASS
NUMBER OF TESTS PASSED : 169
PREV 24 HOURS : 101
SINCE MIDNIGHT :
0.20 GAL/HR RESULTS:
AUG 5.2025 2:34AM PASS
AUG 1.2025 5:16AM PASS
JUL 28.2025 2:44AM PASS
JUL 24.2025 2:17AM PASS
JUL 20.2025 2:17AM PASS
JUL 16.2025 11:37PM PASS
JUL 14.2025 5:12AM PASS
JUL 10.2025 4:07AM PASS
JUL 6.2025 11:55PM PASS
JUL 4.2025 12:47AM PASS
0.10 GAL/HR RESULTS:
JUN 30.2025 4:36AM PASS
DEC 28.2024 6:30AM PASS
JUL 9.2023 1:42AM PASS
JAN 2.2023 1:32AM PASS
JUN 30.2022 3:44AM PASS
DEC 27.2022 12:11AM PASS
JUN 25.2021 1:28AM PASS
DEC 21.2021 4:17AM PASS
JUN 20.2020 2:18AM PASS
DEC 17.2019 3:23AM PASS

Q 2:PREMIUM
3.0 GAL/HR RESULTS:
LAST TEST:
AUG 8.2025 3:23PM PASS
NUMBER OF TESTS PASSED : 145
PREV 24 HOURS : 90
SINCE MIDNIGHT :
0.20 GAL/HR RESULTS:
AUG 8.2025 12:28AM PAS
AUG 5.2025 2:33AM PAS
AUG 1.2025 9:24PM PAS
JUL 30.2025 2:50AM PAS
JUL 26.2025 11:22PM PAS
JUL 24.2025 4:57AM PAS
JUL 20.2025 2:16AM PAS
JUL 16.2025 2:16AM PAS
JUL 12.2025 10:49PM PAS
JUL 10.2025 3:52AM PAS
0.10 GAL/HR RESULTS:
JUL 6.2025 3:53AM PAS
JAN 3.2025 10:20PM PAS
JUL 3.2024 5:27AM PAS
JAN 1.2024 10:52PM PAS
JUL 3.2023 2:43AM PAS
DEC 31.2022 4:15AM PAS
JUN 30.2022 3:43AM PAS
DEC 28.2021 2:03AM PAS
JUN 27.2021 5:11AM PAS
DEC 25.2020 4:40AM PAS

***** END *****