

RIDGE 66
4575 W. 37TH AVE.
HOBART, IN 46342

FEB 6, 2025 1:32 PM

CSLD TEST RESULTS

FEB 6, 2025 1:32 PM

T 1:UNLEADED

PROBE SERIAL NUM 433113

0.2 GAL/HR TEST

PER: FEB 6, 2025 PASS

T 2:PREMIUM

PROBE SERIAL NUM 174990

0.2 GAL/HR TEST

PER: FEB 6, 2025 PASS

* * * * * END * * * * *

RIDGE 66
4575 W. 37TH AVE.
HOBART, IN 46342

FEB 6, 2025 1:32 PM

LEAK TEST REPORT

T 1:UNLEADED

PROBE SERIAL NUM 433113

TEST STARTING TIME:

JUN 24, 2016 8:20 AM

HEIGHT = 51.8 INCHES

WATER = 0.0 INCHES

TEMP = 72.5 F

TEST LENGTH = 2.0 HRS

STRT VOLUME = 6848.1 GAL

PERCENT VOLUME = 58.6

LEAK TEST RESULTS

0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:

TEMP CHANGE TOO LARGE

PRODUCT LEVEL INCREASE

* * * * * END * * * * *

RIDGE 66
4575 W. 37TH AVE.
HOBART, IN 46342

FEB 6, 2025 1:32 PM

LEAK TEST REPORT

T 2:PREMIUM

PROBE SERIAL NUM 174990

NO TEST DATA AVAILABLE

* * * * * END * * * * *