

RIDGE 66
4575 W. 37TH AVE.
HOBART, IN 46342

MAR 5, 2025 11:34 AM

CSLD TEST RESULTS

MAR 5, 2025 11:34 AM

T 1: UNLEADED
PROBE SERIAL NUM 433113

0.2 GAL/HR TEST
PER: MAR 5, 2025 PASS

T 2: PREMIUM
PROBE SERIAL NUM 174990

0.2 GAL/HR TEST
PER: MAR 5, 2025 PASS

* * * * * END * * * * *

RIDGE 66
4575 W. 37TH AVE.
HOBART, IN 46342

MAR 5, 2025 11:34 AM

CSLD TEST RESULTS

MAR 5, 2025 11:34 AM

T 1: UNLEADED
PROBE SERIAL NUM 433113

0.2 GAL/HR TEST
PER: MAR 5, 2025 PASS

T 2: PREMIUM
PROBE SERIAL NUM 174990

0.2 GAL/HR TEST
PER: MAR 5, 2025 PASS

* * * * * END * * * * *

LEAK TEST STATUS:
TEST NOT IN PROGRESS