

RIDGE 66
4575 W. 37TH AVE.
HOBART, IN 46342

APR 9, 2025 4:07 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 433113

TEST STARTING TIME:
JUN 24, 2016 8:20 AM

HEIGHT = 51.8 INCHES
WATER = 0.0 INCHES
TEMP = 72.5 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 6848.1 GAL
PERCENT VOLUME = 58.6

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
TEMP CHANGE TOO LARGE
PRODUCT LEVEL INCREASE

***** END *****

RIDGE 66
4575 W. 37TH AVE.
HOBART, IN 46342

APR 9, 2025 4:07 PM

LEAK TEST REPORT

T 1:UNLEADED
PROBE SERIAL NUM 433113

TEST STARTING TIME:
JUN 24, 2016 8:20 AM

HEIGHT = 51.8 INCHES
WATER = 0.0 INCHES
TEMP = 72.5 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 6848.1 GAL
PERCENT VOLUME = 58.6

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
TEMP CHANGE TOO LARGE
PRODUCT LEVEL INCREASE

***** END *****

RIDGE 66
4575 W. 37TH AVE.
HOBART, IN 46342

APR 9, 2025 4:07 PM

CSLD TEST RESULTS

APR 9, 2025 4:07 PM

T 1:UNLEADED
PROBE SERIAL NUM 433113

0.2 GAL/HR TEST
PER: APR 9, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 174990

0.2 GAL/HR TEST
PER: APR 9, 2025 PASS

***** END *****

RIDGE 66
4575 W. 37TH AVE.
HOBART, IN 46342

APR 9, 2025 4:07 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 174990

NO TEST DATA AVAILABLE

***** END *****

RIDGE 66
4575 W. 37TH AVE.
HOBART, IN 46342

APR 9, 2025 4:07 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 174990

NO TEST DATA AVAILABLE

***** END *****