

ESTABROOK PRECISION LINE TEST

Facility Name: CITGO
 Facility Address: 4575 W 37TH AVENUE HOBART IN 46342
 Facility ID: 5211

Test Date: 01/10/2025
 Technician Name: Seamus Polanski
 Technician Cert #: 021003

Applied Pressure: 50 PSI

#1 Product Type: Regular					
TIME	DATA	-/+	GPL	RES	GPH
3:00	55	0	0.0037	0.0000	0.0000
3:15	55	0	0.0037	0.0000	0.0000
3:30	55	0	0.0037	0.0000	0.0000
FINAL RESULT: PASS					

#2 Product Type: Premium					
TIME	DATA	-/+	GPL	RES	GPH
3:00	76	0	0.0037	0.0000	0.0000
3:15	76	0	0.0037	0.0000	0.0000
3:30	76	0	0.0037	0.2812	1.1248
FINAL RESULT: PASS					

#3 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#4 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#5 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#6 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

DATA = Numbered line increments on site glass.
 -/+ = Change from previous 15-minute reading.
 GPL = Gallons per Line on site glass.
 RES = Result. Gain or loss of lines X .0037
 GPH = Gallons per Hour. RES X 4

PASS Requirements:

3 consecutive readings within .020 GPH of each other
 and final reading less than .050 GPH.

Technician Name: Seamus Polanski

Dispatch # 410566

B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19