

RIDGE 66
4575 W. 37TH AVE.
HOBART, IN 46342

AUG 8. 2025 3:30 PM

CSLD TEST RESULTS

- - - - -
AUG 8. 2025 3:30 PM

T 1: UNLEADED
PROBE SERIAL NUM 433113

0.2 GAL/HR TEST
PER: AUG 8. 2025 PASS

T 2: PREMIUM
PROBE SERIAL NUM 174990

0.2 GAL/HR TEST
PER: AUG 8. 2025 PASS

* * * * * END * * * * *