



5296 Breakers Way, Carmel, IN 46033

Date

3/26/25

PRODUCT LINE TEST

Test Location Information

Name	FID 15886
Address	800 West 61st Ave
City	Merrillville, IN 46410
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
12:20pm	90	0	0.0037	0	0
12:35pm	90	0	0.0037	0	0
12:50pm	90	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
1:05pm	89	0	0.0037	0	0
1:20pm	89	0	0.0037	0	0
1:35pm	89	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : Pass					

#3 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					

#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
Final Result : .					



5296 Breakers Way, Carmel, IN 46033

Date 3/26/25

PRODUCT LINE TEST

Test Location Information

Name	FID 15886
Address	800 West 61st Ave
City	Merrillville, IN 46410
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3		.
4		.
5		.
6		.

Comment :

Tester's Name : Josh Rider

Tester's Signature : 