

PRINCE CITGO
800 WEST 61ST AVE
MERRILLVILLE IN46410
219-961-2866

AUG 8, 2025 12:34 PM

CSLD TEST RESULTS

AUG 8, 2025 12:34 PM

T 1:12K UNLEADED
PROBE SERIAL NUM 496493

0.2 GAL/HR TEST
PER: AUG 8, 2025 PASS

T 2:4K PREMIUM
PROBE SERIAL NUM 496491

0.2 GAL/HR TEST
PER: AUG 8, 2025 PASS

* * * * * END * * * * *

PRINCE CITGO
800 WEST 61ST AVE
MERRILLVILLE IN46410
219-961-2866

AUG 8, 2025 12:34 PM

LIQUID STATUS

AUG 8, 2025 12:34 PM

L 1:DISP 1-2
SENSOR NORMAL

L 2:DISP 3-4
SENSOR NORMAL

L 3:DISP 5-6
SENSOR NORMAL

L 4:REG INT
SENSOR NORMAL

L 6:REG STP
SENSOR NORMAL

L 7:PREM STP
SENSOR NORMAL

L 8:DISP 7-8
SENSOR NORMAL

* * * * * END * * * * *