

PRINCE CITGO
800 WEST 61ST AVE
MERRILLVILLE IN46410
219-961-2866

JUN 10, 2025 1:24 PM

CSLD TEST RESULTS

JUN 10, 2025 1:24 PM

T 1:12K UNLEADED
PROBE SERIAL NUM 496493

0.2 GAL/HR TEST
PER: JUN 10, 2025 PASS

T 2:4K PREMIUM
PROBE SERIAL NUM 496491

0.2 GAL/HR TEST
PER: JUN 10, 2025 PASS

* * * * * END * * * * *

PRINCE CITGO
800 WEST 61ST AVE
MERRILLVILLE IN46410
219-961-2866

JUN 10, 2025 1:24 PM

LIQUID STATUS

JUN 10, 2025 1:24 PM

L 1:DISP 1-2
SENSOR NORMAL

L 2:DISP 3-4
SENSOR NORMAL

L 3:DISP 5-6
SENSOR NORMAL

L 4:REG INT
SENSOR NORMAL

L 6:REG STP
SENSOR NORMAL

L 7:PREM STP
SENSOR NORMAL

L 8:DISP 7-8
SENSOR NORMAL

* * * * * END * * * * *

PRINCE CITGO
800 WEST 61ST AVE
MERRILLVILLE IN46410
219-961-2866

JUN 10, 2025 1:24 PM

LEAK TEST REPORT

T 1:12K UNLEADED
PROBE SERIAL NUM 496493

NO TEST DATA AVAILABLE

* * * * * END * * * * *

PRINCE CITGO
800 WEST 61ST AVE
MERRILLVILLE IN46410
219-961-2866

JUN 10, 2025 1:25 PM

LEAK TEST REPORT

T 2:4K PREMIUM
PROBE SERIAL NUM 496491

NO TEST DATA AVAILABLE

* * * * * END * * * * *