

6/10/25 2:39 PM

itgo
101 Broadway
Merrillville, IN

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

1: Regular West

REPORT TYPE = LAST GROSS
DATE/TIME = 06/09/25 23:13
METHOD = SLD Gross Test
VG. VOLUME = 5845
VOLUME = 50.0

REPORT TYPE = LAST PERIODIC
DATE/TIME = 06/10/25 2:56
METHOD = CSLD Periodic Test
HOURS = 16
VG. VOLUME = 4861
VOLUME = 41.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/03/25 8:20
METHOD = CSLD Periodic Test
HOURS = 16
VG. VOLUME = 5412
VOLUME = 46.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/13/25 23:31
METHOD = CSLD Periodic Test
HOURS = 20
VG. VOLUME = 5785
VOLUME = 49.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/02/25 3:29
METHOD = CSLD Periodic Test
HOURS = 23
VG. VOLUME = 5748
VOLUME = 49.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/05/25 5:16
METHOD = CSLD Periodic Test
HOURS = 16
VG. VOLUME = 6388
VOLUME = 54.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/27/25 1:47
METHOD = CSLD Periodic Test
HOURS = 17
VG. VOLUME = 6265
VOLUME = 53.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/06/25 2:42
METHOD = CSLD Periodic Test
HOURS = 16
VG. VOLUME = 5508
VOLUME = 47.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/09/24 1:12
METHOD = CSLD Periodic Test
HOURS = 14
VG. VOLUME = 5824
VOLUME = 49.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/22/24 8:00
METHOD = CSLD Periodic Test
HOURS = 18
VG. VOLUME = 7352
VOLUME = 62.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/04/24 3:32
METHOD = CSLD Periodic Test
HOURS = 20
VG. VOLUME = 5008
VOLUME = 42.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/20/24 8:00
METHOD = CSLD Periodic Test
HOURS = 18
VG. VOLUME = 5379
VOLUME = 46.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/11/24 6:49
METHOD = CSLD Periodic Test
HOURS = 21
VG. VOLUME = 5578
VOLUME = 47.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/29/24 4:28
METHOD = CSLD Periodic Test
HOURS = 22
VG. VOLUME = 4890
VOLUME = 41.9

FULLEST PERIODIC

6/10/25 2:39 PM

itgo
101 Broadway
Merrillville, IN

RESSURE LINE LEAK REPORTS PASSED TESTS HISTORY

n 1: Regular

Gross Test
Prev 24 Hours 178
Since Midnight 101

Last Gross
Last Periodic 06/10/25 2:34 PM
First Periodic 06/06/25 2:06 AM
06/06/25 2:06 AM

n 2: Premium

Gross Test
Prev 24 Hours 22
Since Midnight 9

Last Gross
Last Periodic 06/10/25 2:35 PM
First Periodic 06/09/25 1:48 AM
06/03/25 12:20 AM

n 3: Diesel

Gross Test
Prev 24 Hours 7
Since Midnight 4

Last Gross
Last Periodic 06/10/25 1:54 PM
First Periodic 06/10/25 9:20 AM
06/02/25 1:08 PM

6/10/25 2:39 PM

itgo
101 Broadway
Merrillville, IN

Sensor Status Report - All Sensors

Sensor Location	Status
1 Disp 1-2	NORMAL
2 Disp 3-4	NORMAL
3 Disp 5-6	NORMAL
4 Disp 7-8	NORMAL
5 Disp 9-10	NORMAL
6 Disp 11-12	NORMAL
7 Regular W STP	NORMAL
8 Regular E STP	NORMAL
9 Premium STP	NORMAL
10 Diesel STP	NORMAL