

05/08/25 1:20 PM

Citgo
6101 Broadway
Merrillville, IN

PRESSURE LINE LEAK REPORTS PASSED TESTS HISTORY

1: Regular

Cross Test
Prev 24 Hours 168
Since Midnight 78

Last Gross 05/08/25 1:19 PM
Last Periodic 05/07/25 3:06 AM

First Periodic 05/01/25 2:20 AM

2: Premium

Cross Test
Prev 24 Hours 23
Since Midnight 10

Last Gross 05/08/25 12:55 PM
Last Periodic 05/07/25 8:27 PM

First Periodic 05/01/25 4:29 AM

3: Diesel

Cross Test
Prev 24 Hours 5
Since Midnight 4

Last Gross 05/08/25 1:11 PM
Last Periodic 05/05/25 9:14 AM

First Periodic 05/01/25 11:38 AM

05/08/25 1:20 PM

Citgo
6101 Broadway
Merrillville, IN

Selected Range:
05/01/25 12:00 AM - 05/08/25 11:59 PM

Sensor Status History Report - All Sensors

Sensor Location	Status
1 Disp 1-2	NORMAL
2 Disp 3-4	NORMAL
3 Disp 5-6	NORMAL
4 Disp 7-8	NORMAL
5 Disp 9-10	NORMAL
6 Disp 11-12	NORMAL
7 Regular W STP	NORMAL
8 Regular E STP	NORMAL
9 Premium STP	NORMAL
10 Diesel STP	NORMAL

05/08/25 1:21 PM

Citgo
6101 Broadway
Merrillville, IN

Selected Range:
05/01/25 12:00 AM - 05/08/25 11:59 PM

Sensor Status History Report - All Sensors

Sensor Location	Status
1 Disp 1-2	NORMAL
2 Disp 3-4	NORMAL
3 Disp 5-6	NORMAL
4 Disp 7-8	NORMAL
5 Disp 9-10	NORMAL
6 Disp 11-12	NORMAL
7 Regular W STP	NORMAL
8 Regular E STP	NORMAL
9 Premium STP	NORMAL
10 Diesel STP	NORMAL

05/08/25 1:19 PM

5:itgo
101 Broadway
Terrillville, IN

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

A
A 3: Premium

REPORT TYPE	= LAST GROSS
DATE/TIME	= 05/08/25 11:59
METHOD	= SLD Gross Test
AVG. VOLUME	= 1783
% VOLUME	= 22.2
REPORT TYPE	= LAST PERIODIC
DATE/TIME	= 05/08/25 9:42
METHOD	= CSLD Periodic Test
HOURS	= 30
AVG. VOLUME	= 1339
% VOLUME	= 16.7
REPORT TYPE	= FULLEST PERIODIC
DATE/TIME	= 05/01/25 3:26
METHOD	= CSLD Periodic Test
HOURS	= 29
AVG. VOLUME	= 1412
% VOLUME	= 17.6
REPORT TYPE	= FULLEST PERIODIC
DATE/TIME	= 04/16/25 22:33
METHOD	= CSLD Periodic Test
HOURS	= 28
AVG. VOLUME	= 1876
% VOLUME	= 23.4
REPORT TYPE	= FULLEST PERIODIC
DATE/TIME	= 03/12/25 20:08
METHOD	= CSLD Periodic Test
HOURS	= 31
AVG. VOLUME	= 1957
% VOLUME	= 24.4
REPORT TYPE	= FULLEST PERIODIC
DATE/TIME	= 02/13/25 8:32
METHOD	= CSLD Periodic Test
HOURS	= 27
AVG. VOLUME	= 2226
% VOLUME	= 27.7
REPORT TYPE	= FULLEST PERIODIC
DATE/TIME	= 01/19/25 8:19
METHOD	= CSLD Periodic Test
HOURS	= 28
AVG. VOLUME	= 2016
% VOLUME	= 25.1
REPORT TYPE	= FULLEST PERIODIC
DATE/TIME	= 12/08/24 20:05
METHOD	= CSLD Periodic Test
HOURS	= 28
AVG. VOLUME	= 1940
% VOLUME	= 24.2
REPORT TYPE	= FULLEST PERIODIC
DATE/TIME	= 11/07/24 20:16
METHOD	= CSLD Periodic Test
HOURS	= 30
AVG. VOLUME	= 1954
% VOLUME	= 24.3
REPORT TYPE	= FULLEST PERIODIC
DATE/TIME	= 10/02/24 1:53
METHOD	= CSLD Periodic Test
HOURS	= 32
AVG. VOLUME	= 1971
% VOLUME	= 24.5
REPORT TYPE	= FULLEST PERIODIC
DATE/TIME	= 09/30/24 11:09
METHOD	= CSLD Periodic Test
HOURS	= 28
AVG. VOLUME	= 1964
% VOLUME	= 24.5
REPORT TYPE	= FULLEST PERIODIC
DATE/TIME	= 08/10/24 6:19
METHOD	= CSLD Periodic Test

05/08/25 1:19 PM

101 Broadway
Merrillville, IN

TANK LEAK TEST HISTORY - PASSED TEST RESULTS

2: Regular E

REPORT TYPE = LAST GROSS
DATE/TIME = 05/08/25 2:37
METHOD = SLD Gross Test
AVG. VOLUME = 4742
VOLUME = 59.1

REPORT TYPE = LAST PERIODIC
DATE/TIME = 05/08/25 3:39
METHOD = CSLD Periodic Test
HOURS = 24
AVG. VOLUME = 3085
VOLUME = 38.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/08/25 3:39
METHOD = CSLD Periodic Test
HOURS = 24
AVG. VOLUME = 3085
VOLUME = 38.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/06/25 1:41
METHOD = CSLD Periodic Test
HOURS = 21
AVG. VOLUME = 3894
VOLUME = 48.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/06/25 23:57
METHOD = CSLD Periodic Test
HOURS = 17
AVG. VOLUME = 4205
VOLUME = 52.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/28/25 2:50
METHOD = CSLD Periodic Test
HOURS = 23
AVG. VOLUME = 4047
VOLUME = 50.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/14/25 3:27
METHOD = CSLD Periodic Test
HOURS = 17
AVG. VOLUME = 3911
VOLUME = 48.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/29/24 3:32
METHOD = CSLD Periodic Test
HOURS = 17
AVG. VOLUME = 3665
VOLUME = 45.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/22/24 2:19
METHOD = CSLD Periodic Test
HOURS = 14
AVG. VOLUME = 4752
VOLUME = 59.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/01/24 2:47
METHOD = CSLD Periodic Test
HOURS = 21
AVG. VOLUME = 3111
VOLUME = 38.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/20/24 8:00
METHOD = CSLD Periodic Test
HOURS = 21
AVG. VOLUME = 3457
VOLUME = 43.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/14/24 2:33

5/08/25 1:19 PM

litgo
101 Broadway
Merrillville, IN

ANK LEAK TEST HISTORY -
PASSED TEST RESULTS

1: Regular West

REPORT TYPE = LAST GROSS
DATE/TIME = 05/08/25 2:37
METHOD = SLD Gross Test
AVG. VOLUME = 6988
VOLUME = 59.8

REPORT TYPE = LAST PERIODIC
DATE/TIME = 05/08/25 3:39
METHOD = CSLD Periodic Test
DURATION = 19
AVG. VOLUME = 5600
VOLUME = 47.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/08/25 3:39
METHOD = CSLD Periodic Test
DURATION = 19
AVG. VOLUME = 5600
VOLUME = 47.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/02/25 3:29
METHOD = CSLD Periodic Test
DURATION = 23
AVG. VOLUME = 5748
VOLUME = 49.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/05/25 5:16
METHOD = CSLD Periodic Test
DURATION = 16
AVG. VOLUME = 6388
VOLUME = 54.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/27/25 1:47
METHOD = CSLD Periodic Test
DURATION = 17
AVG. VOLUME = 6265
VOLUME = 53.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/06/25 2:42
METHOD = CSLD Periodic Test
DURATION = 16
AVG. VOLUME = 5508
VOLUME = 47.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/09/24 1:12
METHOD = CSLD Periodic Test
DURATION = 14
AVG. VOLUME = 5824
VOLUME = 49.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/22/24 8:00
METHOD = CSLD Periodic Test
DURATION = 18
AVG. VOLUME = 7352
VOLUME = 62.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/04/24 3:32
METHOD = CSLD Periodic Test
DURATION = 20
AVG. VOLUME = 5008
VOLUME = 42.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/20/24 8:00
METHOD = CSLD Periodic Test
DURATION = 18
AVG. VOLUME = 5379
VOLUME = 46.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/11/24 6:49
METHOD = CSLD Periodic Test
DURATION = 21