

ANNUAL OPERATIONAL TESTING REPORT

Facility Name: MERRILLVILLE CITGO/ROOP PETROLEUM INC Test Date: 06/20/2024
Facility Address: 6101 BROADWAY MERRILLVILLE IN 46410
Facility ID: 9858

SHEAR VALVE INSPECTION

Dispenser #	Product	Anchored Properly	Proper Height	Functionality Test
1-2	Regular	PASS	PASS	PASS
1-2	Premium	PASS	PASS	PASS
3-4	Regular	PASS	PASS	PASS
3-4	Premium	PASS	PASS	PASS
5-6	Regular	PASS	PASS	PASS
5-6	Premium	PASS	PASS	PASS
7-8	Regular	PASS	PASS	PASS
7-8	Premium	PASS	PASS	PASS
9-10	Regular	PASS	PASS	PASS
9-10	Premium	PASS	PASS	PASS
9-10	Diesel	PASS	PASS	PASS
11-12	Regular	PASS	PASS	PASS
11-12	Premium	PASS	PASS	PASS
11-12	Diesel	PASS	PASS	PASS

Comments

EMERGENCY STOP INSPECTION

# of Switches Tested	# of Switches Passed
1	1

Comments

Technician Name: Seamus Polanski

Technician Signature:

Dispatch # 403715

B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19

