

GO LO
6851 BROADWAY
MERRILLVILLE IN

FEB 6, 2025 17:06

CSLD TEST RESULTS

FEB 6, 2025 17:06

T 1:REGULAR
PROBE SERIAL NUM 294064

0.2 GAL/HR TEST
PER: FEB 5, 2025 PASS

T 2:REG SLAVE
PROBE SERIAL NUM 294063

0.2 GAL/HR TEST
PER: FEB 5, 2025 PASS

T 3:PREMIUM
PROBE SERIAL NUM 294065

0.2 GAL/HR TEST
PER: FEB 6, 2025 PASS

* * * * * END * * * * *

GO LO
6851 BROADWAY
MERRILLVILLE IN

FEB 6, 2025 17:06

LIQUID STATUS

FEB 6, 2025 17:06

NONE

* * * * * END * * * * *

GO LO
6851 BROADWAY
MERRILLVILLE IN

FEB 6, 2025 17:06

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:
FEB 6, 2025 17:01 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 112
SINCE MIDNIGHT : 81

0.20 GAL/HR RESULTS:

FEB	6,	2025	2:48	FAIL
FEB	2,	2025	23:28	FAIL
JAN	29,	2025	6:09	FAIL
JAN	21,	2025	3:23	FAIL
JAN	21,	2025	2:11	FAIL
JAN	19,	2025	21:52	FAIL
JAN	19,	2025	7:55	FAIL
JAN	19,	2025	4:08	FAIL
JAN	19,	2025	2:52	FAIL
JAN	16,	2025	0:05	FAIL

0.10 GAL/HR RESULTS:

JUL	15,	2024	10:41	PASS
JAN	13,	2024	3:02	PASS
JUN	27,	2023	3:09	PASS
DEC	25,	2022	4:18	PASS
MAY	21,	2022	2:04	PASS
NOV	10,	2021	2:15	PASS
MAY	1,	2021	0:32	PASS
OCT	22,	2020	2:28	PASS
APR	8,	2020	0:18	PASS
OCT	4,	2019	3:05	PASS

Q 3:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:

FEB 6, 2025 16:32 PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 31

SINCE MIDNIGHT : 24

0.20 GAL/HR RESULTS:

FEB	6,	2025	9:24	FAIL
FEB	4,	2025	17:35	FAIL
FEB	4,	2025	5:29	FAIL
FEB	2,	2025	9:55	FAIL
JAN	31,	2025	20:23	FAIL
JAN	29,	2025	19:53	FAIL
JAN	29,	2025	2:07	FAIL
JAN	27,	2025	18:23	FAIL
JAN	27,	2025	6:52	FAIL
JAN	25,	2025	19:11	FAIL

0.10 GAL/HR RESULTS:

AUG	14,	2024	4:44	PASS
FEB	13,	2024	0:29	PASS
AUG	14,	2023	9:44	PASS
FEB	12,	2023	0:00	PASS
AUG	13,	2022	7:49	PASS
FEB	11,	2022	0:01	PASS
AUG	12,	2021	3:54	PASS
FEB	9,	2021	19:27	PASS
AUG	9,	2020	19:58	PASS
FEB	9,	2020	1:31	PASS

* * * * * END * * * * *