

30 DAYS WALK THROUGH INSPECTION

Tanks Data

UST Facility I.D. (FID) # 22613

Contact Number

Facility Name Mobile

Contact email

Address 6851 Ryno Avenue

Date of Inspection

0315125

Operator on Duty Name

Name of the Person Conducting Inspection

ANKIT

Operator Training current

Operator Training
☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Release Detection Method

Release Detection
☒ ATG ☐ DIM

☐ SIR

☐ IC

☐ Other

Make and Model

VR-TLS-3505

Does it have paper?

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Necessary Monthly Printout Taken

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Spill Buckets

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Fill Ports

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Piping/STP Sumps

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Under Dispenser Containments (UDC)

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

☒ Yes ☐ No

Operator Notified

☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com