

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 22613		Contact Number
Facility Name M081L		Contact email
Address 6851 Broadway, Merrillville, IN 46410		Date of Inspection 02/06/25
Operator on Duty Name		Name of the Person Conducting Inspection AKM/T

	Operator Training		Registration/Notification Form		Release Detection	
	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No
Operator Training current	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	☐ Yes	☐ No	☐ Yes	☐ No
Release Detection Method	☒ ATG	☐ TIM	☐ BIR	☐ IC	☐ Other	
Make and Model	VR TL 5350J					
Does it have paper?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No	
Is it in Alarm mode?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No	
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No	
Necessary Monthly Printout Taken	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No	
Spill Buckets	☐ Yes	☒ No	Operator Notified	☒ Yes	☐ No	
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No	
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No	
Fill Ports	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	
Piping/STP Sumps	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	
Under Dispenser Containments (UDC)	☐ Yes	☐ No	Operator Notified	☐ Yes	☐ No	
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☐ Yes	☐ No	

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215	tanksdata@gmail.com	www.tanksdata.com