

GO LO
6851 BROADWAY
MERRILLVILLE IN

JUN 10, 2025 14:31

CSLD TEST RESULTS

JUN 10, 2025 14:31

T 1:REGULAR
PROBE SERIAL NUM 294064

0.2 GAL/HR TEST
PER: JUN 10, 2025 PASS

T 2:REG SLAVE
PROBE SERIAL NUM 294063

0.2 GAL/HR TEST
PER: JUN 10, 2025 PASS

T 3:PREMIUM
PROBE SERIAL NUM 294065

0.2 GAL/HR TEST
PER: JUN 10, 2025 PASS

* * * * * END * * * * *

GO LO
6851 BROADWAY
MERRILLVILLE IN

JUN 10, 2025 14:31

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:
JUN 10, 2025 14:25 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 138

SINCE MIDNIGHT : 66

0.20 GAL/HR RESULTS:

JUN 10, 2025 5:35 PASS

JUN 6, 2025 21:17 PASS

JUN 4, 2025 1:16 PASS

MAY 31, 2025 3:04 PASS

MAY 27, 2025 21:33 PASS

MAY 23, 2025 0:55 PASS

MAY 17, 2025 4:44 PASS

MAY 13, 2025 23:13 PASS

MAY 9, 2025 3:10 PASS

MAY 3, 2025 5:07 PASS

0.10 GAL/HR RESULTS:

JUL 15, 2024 10:41 PASS

JAN 13, 2024 3:02 PASS

JUN 27, 2023 3:09 PASS

DEC 25, 2022 4:18 PASS

MAY 21, 2022 2:04 PASS

NOV 10, 2021 2:15 PASS

MAY 1, 2021 0:32 PASS

OCT 22, 2020 2:28 PASS

APR 8, 2020 0:18 PASS

OCT 4, 2019 3:05 PASS

Q 3:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
JUN 10, 2025 14:25 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 30

SINCE MIDNIGHT : 13

0.20 GAL/HR RESULTS:

JUN 10, 2025 6:57 PASS

JUN 6, 2025 19:18 PASS

JUN 4, 2025 4:46 PASS

JUN 31, 2025 20:04 PASS

MAY 29, 2025 5:35 PASS

MAY 25, 2025 11:11 PASS

MAY 21, 2025 16:26 PASS

MAY 19, 2025 1:55 PASS

MAY 15, 2025 18:58 PASS

MAY 13, 2025 4:21 PASS

0.10 GAL/HR RESULTS:

AUG 14, 2024 4:44 PASS

FEB 13, 2024 0:29 PASS

AUG 14, 2023 9:44 PASS

FEB 12, 2023 0:00 PASS

AUG 13, 2022 7:49 PASS

FEB 11, 2022 0:01 PASS

AUG 12, 2021 3:54 PASS

AUG 12, 2021 19:27 PASS

GO LO
6851 BROADWAY
MERRILLVILLE IN

JUN 10, 2025 14:31

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:
JUN 10, 2025 14:25 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 138
SINCE MIDNIGHT : 66

0.20 GAL/HR RESULTS:

JUN 10, 2025	5:35	PASS
JUN 6, 2025	21:17	PASS
JUN 4, 2025	1:16	PASS
MAY 31, 2025	3:04	PASS
MAY 27, 2025	21:33	PASS
MAY 23, 2025	0:55	PASS
MAY 17, 2025	4:44	PASS
MAY 13, 2025	23:13	PASS
MAY 9, 2025	3:10	PASS
MAY 3, 2025	5:07	PASS

0.10 GAL/HR RESULTS:

JUL 15, 2024	10:41	PASS
JAN 13, 2024	3:02	PASS
JUN 27, 2023	3:09	PASS
DEC 25, 2022	4:18	PASS
MAY 21, 2022	2:04	PASS
NOV 10, 2021	2:15	PASS
MAY 1, 2021	0:32	PASS
OCT 22, 2020	2:28	PASS
APR 8, 2020	0:18	PASS
OCT 4, 2019	3:05	PASS

Q 3:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
JUN 10, 2025 14:25 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 30
SINCE MIDNIGHT : 13

0.20 GAL/HR RESULTS:

JUN 10, 2025	6:57	PASS
JUN 6, 2025	19:18	PASS
JUN 4, 2025	4:46	PASS
MAY 31, 2025	20:04	PASS
MAY 29, 2025	5:35	PASS
MAY 25, 2025	11:11	PASS
MAY 21, 2025	16:26	PASS
MAY 19, 2025	1:55	PASS
MAY 15, 2025	18:58	PASS
MAY 13, 2025	4:21	PASS

0.10 GAL/HR RESULTS:

AUG 14, 2024	4:44	PASS
FEB 13, 2024	0:29	PASS
AUG 14, 2023	9:44	PASS
FEB 12, 2023	0:00	PASS
AUG 13, 2022	7:49	PASS
FEB 11, 2022	0:01	PASS
AUG 12, 2021	3:54	PASS
FEB 9, 2021	19:27	PASS
AUG 9, 2020	19:58	PASS
FEB 9, 2020	1:31	PASS

* * * * * END * * * * *

GO LO
6851 BROADWAY
MERRILLVILLE IN

JUN 10, 2025 14:31

LIQUID STATUS

JUN 10, 2025 14:31

NONE

* * * * * END * * * * *