

GO LO
6851 BROADWAY
MERRILLVILLE IN

AUG 8, 2025 14:00

COLD TEST RESULTS

AUG 8, 2025 14:00

T 1:REGULAR
PROBE SERIAL NUM 294064

0.2 GAL/HR TEST
PER: AUG 8, 2025 PASS

T 2:REG SLAVE
PROBE SERIAL NUM 294063

0.2 GAL/HR TEST
PER: AUG 8, 2025 PASS

T 3:PREMIUM
PROBE SERIAL NUM 294065

0.2 GAL/HR TEST
PER: AUG 8, 2025 PASS

* * * * * END * * * * *

GO LO
6851 BROADWAY
MERRILLVILLE IN

AUG 8, 2025 14:00

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:
AUG 8, 2025 13:59 PASS

NUMBER OF TESTS PASSED 143
PREV 24 HOURS : 78

SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

AUG 7, 2025 2:01 PASS

AUG 3, 2025 4:56 PASS

JUL 28, 2025 3:01 PASS

JUL 24, 2025 0:46 PASS

JUL 20, 2025 4:40 PASS

JUL 16, 2025 2:03 PASS

JUL 12, 2025 23:17 PASS

JUL 10, 2025 1:32 PASS

JUL 4, 2025 3:53 PASS

JUN 30, 2025 0:49 PASS

0.10 GAL/HR RESULTS:

JUL 15, 2024 10:41 PASS

JAN 13, 2024 3:02 PASS

JUN 27, 2023 3:09 PASS

DEC 25, 2022 4:18 PASS

MAY 21, 2022 2:04 PASS

NOV 10, 2021 2:15 PASS

MAY 1, 2021 0:32 PASS

OCT 22, 2020 2:28 PASS

APR 8, 2020 0:18 PASS

OCT 4, 2019 3:05 PASS

Q 3:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
AUG 8, 2025 13:36 PASS

NUMBER OF TESTS PASSED 30
PREV 24 HOURS : 17

SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

AUG 7, 2025 0:35 PASS

AUG 3, 2025 8:36 PASS

JUL 30, 2025 20:55 PASS

JUL 28, 2025 4:43 PASS

JUL 24, 2025 8:54 PASS

JUL 20, 2025 20:48 PASS

JUL 18, 2025 3:56 PASS

JUL 14, 2025 19:16 PASS

JUL 12, 2025 4:04 PASS

JUL 8, 2025 15:40 PASS

0.10 GAL/HR RESULTS:

AUG 14, 2024 4:44 PASS

FEB 13, 2024 0:29 PASS

AUG 14, 2023 9:44 PASS

FEB 12, 2023 0:00 PASS

AUG 13, 2022 7:49 PASS

FEB 11, 2022 0:01 PASS

AUG 12, 2021 3:54 PASS

FEB 9, 2021 19:27 PASS

AUG 9, 2020 19:58 PASS

FEB 9, 2020 1:31 PASS

GO LO
6851 BROADWAY
MERRILLVILLE IN

AUG 8, 2025 14:00

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:
AUG 8, 2025 13:59 PASS

NUMBER OF TESTS PASSED 143
PREV 24 HOURS : 78
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

AUG 7, 2025	2:01	PASS
AUG 3, 2025	4:56	PASS
JUL 28, 2025	3:01	PASS
JUL 24, 2025	0:46	PASS
JUL 20, 2025	4:40	PASS
JUL 16, 2025	2:03	PASS
JUL 12, 2025	23:17	PASS
JUL 10, 2025	1:32	PASS
JUL 4, 2025	3:53	PASS
JUN 30, 2025	0:49	PASS

0.10 GAL/HR RESULTS:

JUL 15, 2024	10:41	PASS
JAN 13, 2024	3:02	PASS
JUN 27, 2023	3:09	PASS
DEC 25, 2023	4:18	PASS
MAY 21, 2022	2:04	PASS
NOV 10, 2022	2:15	PASS
MAY 1, 2021	0:32	PASS
OCT 22, 2021	2:28	PASS
APR 8, 2020	0:18	PASS
OCT 4, 2019	3:05	PASS

Q 3:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
AUG 8, 2025 13:36 PASS

NUMBER OF TESTS PASSED 30
PREV 24 HOURS : 17
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

AUG 7, 2025	0:35	PASS
AUG 3, 2025	8:36	PASS
JUL 30, 2025	20:55	PASS
JUL 28, 2025	4:43	PASS
JUL 24, 2025	8:54	PASS
JUL 20, 2025	20:48	PASS
JUL 18, 2025	3:56	PASS
JUL 14, 2025	19:16	PASS
JUL 12, 2025	4:04	PASS
JUL 8, 2025	15:40	PASS

0.10 GAL/HR RESULTS:

AUG 14, 2024	4:44	PASS
FEB 13, 2024	0:29	PASS
AUG 14, 2023	9:44	PASS
FEB 12, 2023	0:00	PASS
AUG 13, 2022	7:49	PASS
FEB 11, 2022	0:01	PASS
AUG 12, 2021	3:54	PASS
FEB 9, 2021	19:27	PASS
AUG 9, 2020	19:58	PASS
FEB 9, 2020	1:31	PASS

* * * * * END * * * * *

GO LO
6851 BROADWAY
MERRILLVILLE IN

AUG 8, 2025 14:00

LIQUID STATUS

AUG 8, 2025 14:00

NONE

* * * * * END * * * * *