



CATHODIC PROTECTION RESULTS DATA SHEET

DATE OF SURVEY: 1/23/2025

Test Location Information

Name	Mobil
Address	6851 Broadway
City	Merrillville, IN
Phone	
Contact	
FACILITY #	

Testing Company Information

Name	Metro Tank And Pump
Address	1111 W Dundee Rd.
City	Wheeling
Phone	847-465-4000

Technician Information

Name	Eric Runowski
Cert #	

TEST LOCATION	ON	INSTANT OFF
1/2	-0.947	
3/4	-1.006	
2/4 Sp	-1.006	
5/6	-0.984	
5/6 Sp	-1.021	
7/8	-1.018	
N STP		
C STP		
S STP		

RECTIFIER SETTINGS:	VOLTS:	AMPS:	HOURS:

TYPE OF SYSTEM:
Galvanic

TEST RESULTS
PASS OR FAIL
Pass

TECHNICIAN SIGNATURE & DATE
Eric Runowski 1-23-25

NOTES:
Post install test STP Sumps were dry Pass