

ESTABROOK PRECISION LINE TEST

Facility Name: PRINCE MOBIL
Facility Address: 6851 BROADWAY MERRILLVILLE IN 46410
Facility ID: 0

Test Date: 07/15/2024
Technician Name: Mark Huizenga
Technician Cert #: 041897

Applied Pressure: 50 PSI

#1 Product Type: RuI					
TIME	DATA	-/+	GPL	RES	GPH
9:00	76	0	0.0037	0.0000	0.0000
9:15	76	0	0.0037	0.0000	0.0000
9:30	76	0	0.0037	0.0000	0.0000
FINAL RESULT: PASS					

#2 Product Type: PuI					
TIME	DATA	-/+	GPL	RES	GPH
9:00	79	0	0.0037	0.0000	0.0000
9:15	79	0	0.0037	0.0000	0.0000
9:30	79	0	0.0037	0.2923	1.1692
FINAL RESULT: PASS					

#3 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#4 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#5 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

#6 Product Type:					
TIME	DATA	-/+	GPL	RES	GPH
FINAL RESULT:					

DATA = Numbered line increments on site glass.
-/+ = Change from previous 15-minute reading.
GPL = Gallons per Line on site glass.
RES = Result. Gain or loss of lines X .0037
GPH = Gallons per Hour. RES X 4

PASS Requirements:

3 consecutive readings within .020 GPH of each other
and final reading less than .050 GPH.

Technician Name: Mark Huizenga
Dispatch # 404382
B&K Equipment completes testing and inspections per recommended practices of PEI RP1200-19

Technician Signature:

