



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 10/8/25

AUTOMATIC TANK GAUGE FUNCTIONALITY TEST

Facility Name:	Mobile	Owner:	PRINCE PETROLEUM INC
Address:	6851 Broadway	Address:	6851 Broadway
City, State, Zip Code:	Merrillville, IN 46410	City, State, Zip Code:	Merrillville, IN 46410
Facility I.D. #:	22613	Phone #:	

This procedure is to determine whether the automatic tank gauge (ATG) is operating properly. See PEI/RPI200 Section 8.2 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.

Tank Number	1	2	3		
Product Stored	Regular 1	Regular 2	Premium		
ATG Brand and Model	TLS-350	TLS-350	TLS-350		
1. Tank Volume, gallons	10,563	6,380	6,380		
2. Tank Diameter, inches	119	119	119		
3. After removing the ATG from the tank, it has been inspected and any damaged or missing parts replaced?	Yes	Yes	Yes		
4. Float moves freely on the stem without binding?	Yes	Yes	Yes		
5. Fuel float level agrees with the value programmed into the console?	Yes	Yes	Yes		
6. Water float level agrees with the value programmed into the console?	Yes	Yes	Yes		
7. Inch level from bottom of stem when 90% alarm is triggered.	104	104	104		
8. Inch level at which the overfill alarm activates corresponds with value programmed in the gauge?	Yes	Yes	Yes		
9. Inch level from the bottom when the water float first triggers an alarm.	2	2	2		
10. Inch level at which the water float alarm activates corresponds with value programmed in the gauge?	Yes	Yes	Yes		
If any answers in Lines 3, 4, 5, or 6 are "No," the system has failed the test.					
Test Results	Pass	Pass	Pass		

Comment :

Tester's Name : Josh Rider

Tester's Signature : 