

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 22613
Address	6851 Broadway
City	Merrillville
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg 1	Fe Petro ELLD		
Reg 2	Slave		
Prem	Fe Petro ELLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	38	24	870 ml	189ml	2 cycles	Pass
2	Premium	40	26	570 ml	189ml	2 cycles	Pass
3					189ml	.	
4					189ml	.	
5					189ml	.	
6					189ml	.	
7					189ml	.	
8					189ml	.	

Comment:

Regulars are manifolded and Reg 2 does not have a leak detector.

Technician Signature :

Josh Rider