

GO LO
6851 BROADWAY
MERRILLVILLE IN

OCT 8, 2025 11:15

TANK LEAK TEST HISTORY

T 1:REGULAR

LAST GROSS TEST PASSED:
OCT 7, 2025 5:18
STARTING VOLUME= 2245
PERCENT VOLUME = 21.3
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:
OCT 8, 2025 8:00
TEST LENGTH 24 HOURS
STARTING VOLUME= 3152
PERCENT VOLUME = 29.8
TEST TYPE = CSLD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

JAN 24, 2025 3:18
TEST LENGTH 6 HOURS
STARTING VOLUME= 5543
PERCENT VOLUME = 52.5
TEST TYPE = CSLD

FEB 26, 2025 1:02
TEST LENGTH 20 HOURS
STARTING VOLUME= 4142
PERCENT VOLUME = 39.2
TEST TYPE = CSLD

MAR 7, 2025 8:00
TEST LENGTH 8 HOURS
STARTING VOLUME= 5795
PERCENT VOLUME = 54.9
TEST TYPE = CSLD

APR 27, 2025 1:44
TEST LENGTH 23 HOURS
STARTING VOLUME= 4100
PERCENT VOLUME = 38.8
TEST TYPE = CSLD

MAY 3, 2025 7:49
TEST LENGTH 24 HOURS
STARTING VOLUME= 3779
PERCENT VOLUME = 35.8
TEST TYPE = CSLD

JUN 30, 2025 4:04
TEST LENGTH 22 HOURS
STARTING VOLUME= 4329
PERCENT VOLUME = 41.0
TEST TYPE = CSLD

JUL 12, 2025 3:15
TEST LENGTH 23 HOURS
STARTING VOLUME= 4314
PERCENT VOLUME = 40.8
TEST TYPE = CSLD

AUG 20, 2025 2:47
TEST LENGTH 27 HOURS
STARTING VOLUME= 3320
PERCENT VOLUME = 31.4
TEST TYPE = CSLD

SEP 30, 2025 3:02
TEST LENGTH 23 HOURS
STARTING VOLUME= 3591
PERCENT VOLUME = 34.0
TEST TYPE = CSLD

OCT 1, 2025 1:59
TEST LENGTH 25 HOURS
STARTING VOLUME= 3538
PERCENT VOLUME = 33.5
TEST TYPE = CSLD

NOV 4, 2024 2:56
TEST LENGTH 21 HOURS
STARTING VOLUME= 3594
PERCENT VOLUME = 34.0
TEST TYPE = CSLD

DEC 28, 2024 8:00
TEST LENGTH 8 HOURS
STARTING VOLUME= 4715
PERCENT VOLUME = 44.6
TEST TYPE = CSLD

***** END *****

GO LO
6851 BROADWAY
MERRILLVILLE IN

OCT 8, 2025 11:17

TANK LEAK TEST HISTORY

T 2:REG SLAVE

LAST GROSS TEST PASSED:
OCT 7, 2025 5:18
STARTING VOLUME= 2235
PERCENT VOLUME = 35.0
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:
OCT 8, 2025 8:00
TEST LENGTH 18 HOURS
STARTING VOLUME= 4167
PERCENT VOLUME = 65.3
TEST TYPE = CSLD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

JAN 10, 2025 22:21
TEST LENGTH 17 HOURS
STARTING VOLUME= 4576
PERCENT VOLUME = 71.7
TEST TYPE = CSLD

FEB 27, 2025 3:27
TEST LENGTH 15 HOURS
STARTING VOLUME= 4573
PERCENT VOLUME = 71.7
TEST TYPE = CSLD

MAR 31, 2025 7:59
TEST LENGTH 20 HOURS
STARTING VOLUME= 5110
PERCENT VOLUME = 80.1
TEST TYPE = CSLD

APR 23, 2025 3:46
TEST LENGTH 16 HOURS
STARTING VOLUME= 5183
PERCENT VOLUME = 81.3
TEST TYPE = CSLD

MAY 12, 2025 3:09
TEST LENGTH 19 HOURS
STARTING VOLUME= 4584
PERCENT VOLUME = 71.9
TEST TYPE = CSLD

JUN 29, 2025 6:11
TEST LENGTH 18 HOURS
STARTING VOLUME= 4794
PERCENT VOLUME = 75.1
TEST TYPE = CSLD

JUL 11, 2025 6:58
TEST LENGTH 17 HOURS
STARTING VOLUME= 4845
PERCENT VOLUME = 76.0
TEST TYPE = CSLD

AUG 24, 2025 2:22
TEST LENGTH 18 HOURS
STARTING VOLUME= 4198
PERCENT VOLUME = 65.8
TEST TYPE = CSLD

SEP 30, 2025 3:02
TEST LENGTH 19 HOURS
STARTING VOLUME= 4533
PERCENT VOLUME = 71.1
TEST TYPE = CSLD

OCT 3, 2025 4:44
TEST LENGTH 18 HOURS
STARTING VOLUME= 4622
PERCENT VOLUME = 72.5
TEST TYPE = CSLD

NOV 1, 2024 23:35
TEST LENGTH 16 HOURS
STARTING VOLUME= 4758
PERCENT VOLUME = 74.6
TEST TYPE = CSLD

DEC 28, 2024 3:23
TEST LENGTH 14 HOURS
STARTING VOLUME= 4358
PERCENT VOLUME = 68.3
TEST TYPE = CSLD

***** END *****

GO LO
6851 BROADWAY
MERRILLVILLE IN

OCT 8, 2025 11:17

TANK LEAK TEST HISTORY

T 3:PREMIUM

LAST GROSS TEST PASSED:
OCT 8, 2025 10:46
STARTING VOLUME= 2135
PERCENT VOLUME = 33.5
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:
OCT 8, 2025 5:27
TEST LENGTH 29 HOURS
STARTING VOLUME= 1111
PERCENT VOLUME = 17.4
TEST TYPE = CSLD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

JAN 3, 2025 3:41
TEST LENGTH 33 HOURS
STARTING VOLUME= 2225
PERCENT VOLUME = 34.9
TEST TYPE = CSLD

FEB 25, 2025 0:03
TEST LENGTH 33 HOURS
STARTING VOLUME= 1755
PERCENT VOLUME = 27.5
TEST TYPE = CSLD

MAR 31, 2025 20:31
TEST LENGTH 34 HOURS
STARTING VOLUME= 2569
PERCENT VOLUME = 40.3
TEST TYPE = CSLD

APR 6, 2025 7:19
TEST LENGTH 31 HOURS
STARTING VOLUME= 2695
PERCENT VOLUME = 42.2
TEST TYPE = CSLD

MAY 18, 2025 11:03
TEST LENGTH 27 HOURS
STARTING VOLUME= 2346
PERCENT VOLUME = 36.8
TEST TYPE = CSLD

JUN 22, 2025 1:53
TEST LENGTH 29 HOURS
STARTING VOLUME= 2146
PERCENT VOLUME = 33.6
TEST TYPE = CSLD

JUL 30, 2025 22:13
TEST LENGTH 31 HOURS
STARTING VOLUME= 1750
PERCENT VOLUME = 27.4
TEST TYPE = CSLD

AUG 6, 2025 21:41
TEST LENGTH 33 HOURS
STARTING VOLUME= 2003
PERCENT VOLUME = 31.4
TEST TYPE = CSLD

SEP 21, 2025 8:36
TEST LENGTH 34 HOURS
STARTING VOLUME= 1526
PERCENT VOLUME = 23.9
TEST TYPE = CSLD

OCT 3, 2025 15:45
TEST LENGTH 27 HOURS
STARTING VOLUME= 1264
PERCENT VOLUME = 19.8
TEST TYPE = CSLD

NOV 25, 2024 20:22
TEST LENGTH 27 HOURS
STARTING VOLUME= 1880
PERCENT VOLUME = 29.5
TEST TYPE = CSLD

DEC 31, 2024 7:56
TEST LENGTH 28 HOURS
STARTING VOLUME= 2215
PERCENT VOLUME = 34.7
TEST TYPE = CSLD

***** END *****