

GO LO
6851 BROADWAY
MERRILLVILLE IN
SEP 10, 2025 14:28
CBLD TEST RESULTS
SEP 10, 2025 14:28
T 1:REGULAR
PROBE SERIAL NUM 294064
0.2 GAL/HR TEST
PER: SEP 10, 2025 PASS
T 2:REG SLAVE
PROBE SERIAL NUM 294063
0.2 GAL/HR TEST
PER: SEP 10, 2025 PASS
T 3:PREMIUM
PROBE SERIAL NUM 294065
0.2 GAL/HR TEST
PER: SEP 10, 2025 PASS
***** END *****

GO LO
6851 BROADWAY
MERRILLVILLE IN
SEP 10, 2025 14:28
LIQUID STATUS
- - - - -
SEP 10, 2025 14:28
NONE
***** END *****

GO LO
6851 BROADWAY
MERRILLVILLE IN
SEP 10, 2025 14:28
PRESSURE LINE LEAK
TEST RESULTS
Q 1:REGULAR
3.0 GAL/HR RESULTS:
LAST TEST:
SEP 10, 2025 14:21 PASS
NUMBER OF TESTS PASSED
PREV 24 HOURS : 113
SINCE MIDNIGHT : 59

0.20 GAL/HR RESULTS:
SEP 8, 2025 4:26 PASS
SEP 4, 2025 0:36 PASS
AUG 31, 2025 4:17 PASS
AUG 27, 2025 3:41 PASS
AUG 23, 2025 2:43 PASS
AUG 19, 2025 3:31 PASS
AUG 15, 2025 4:51 PASS
AUG 11, 2025 1:05 PASS
AUG 7, 2025 2:01 PASS
AUG 3, 2025 4:56 PASS

0.10 GAL/HR RESULTS:
JUL 15, 2024 10:41 PASS
JAN 13, 2024 3:02 PASS
JUN 27, 2023 3:09 PASS
DEC 25, 2022 4:18 PASS
MAY 21, 2022 2:04 PASS
NOV 10, 2021 2:15 PASS
MAY 1, 2021 0:32 PASS
OCT 22, 2020 2:28 PASS
APR 8, 2020 0:18 PASS
OCT 4, 2019 3:05 PASS

Q 3:PREMIUM
3.0 GAL/HR RESULTS:
LAST TEST:
SEP 10, 2025 14:07 PASS
NUMBER OF TESTS PASSED
PREV 24 HOURS : 27
SINCE MIDNIGHT : 14

GO LO
6851 BROADWAY
MERRILLVILLE IN

SEP 10, 2025 14:28

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:

SEP 10, 2025 14:21 PASS

NUMBER OF TESTS PASSED 113

PREV 24 HOURS : 59

SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

SEP 8, 2025 4:26 PASS

SEP 4, 2025 0:36 PASS

AUG 31, 2025 4:17 PASS

AUG 27, 2025 3:41 PASS

AUG 23, 2025 2:43 PASS

AUG 19, 2025 3:31 PASS

AUG 15, 2025 4:51 PASS

AUG 11, 2025 1:05 PASS

AUG 7, 2025 2:01 PASS

AUG 3, 2025 4:56 PASS

0.10 GAL/HR RESULTS:

JUL 15, 2024 10:41 PASS

JAN 13, 2024 3:02 PASS

JUN 27, 2023 3:09 PASS

DEC 25, 2022 4:18 PASS

MAY 21, 2022 2:04 PASS

NOV 10, 2021 2:15 PASS

MAY 1, 2021 0:32 PASS

OCT 22, 2020 2:28 PASS

APR 8, 2020 0:18 PASS

OCT 4, 2019 3:05 PASS

Q 3:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:

SEP 10, 2025 14:07 PASS

NUMBER OF TESTS PASSED 27

PREV 24 HOURS : 14

SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

SEP 8, 2025 7:00 PASS

SEP 4, 2025 9:53 PASS

AUG 31, 2025 21:25 PASS

AUG 29, 2025 5:12 PASS

AUG 25, 2025 6:09 PASS

AUG 21, 2025 22:22 PASS

AUG 19, 2025 7:12 PASS

AUG 15, 2025 20:11 PASS

AUG 13, 2025 4:10 PASS

AUG 9, 2025 15:08 PASS

0.10 GAL/HR RESULTS:

AUG 14, 2024 4:44 PASS

FEB 13, 2024 0:29 PASS

AUG 14, 2023 9:44 PASS

FEB 12, 2023 0:00 PASS

AUG 13, 2022 7:49 PASS

FEB 11, 2022 0:01 PASS

AUG 12, 2021 3:54 PASS

FEB 9, 2021 19:27 PASS

AUG 9, 2020 19:58 PASS

FEB 9, 2020 1:31 PASS

***** END *****