

GO LO
6851 BROADWAY
MERRILLVILLE IN

OCT 8, 2025 10:50

PRESSURE LINE LEAK TEST
HISTORY

Q 1:REGULAR

LAST 3.0 GAL/HR PASS:

OCT 8, 2025 10:37

FIRST 0.20 GAL/HR PASS
EACH MONTH:

OCT	4, 2025	6:50
SEP	4, 2025	0:36
AUG	3, 2025	4:56
JUL	4, 2025	3:53
JUN	4, 2025	1:16
MAY	3, 2025	5:07
APR	1, 2025	1:31
MAR	29, 2025	1:45
DEC	2, 2024	2:48
NOV	4, 2024	1:23
OCT	3, 2024	1:56
SEP	3, 2024	3:08

FIRST 0.10 GAL/HR PASS
EACH MONTH:

JUL	15, 2024	10:41
JAN	13, 2024	3:02
JUN	27, 2023	3:09
DEC	25, 2022	4:18
MAY	21, 2022	2:04

* * * * * END * * * * *

GO LO
6851 BROADWAY
MERRILLVILLE IN

OCT 8, 2025 10:50

PRESSURE LINE LEAK TEST
HISTORY

Q 3:PREMIUM

LAST 3.0 GAL/HR PASS:

OCT 8, 2025 10:00

FIRST 0.20 GAL/HR PASS
EACH MONTH:

OCT	2, 2025	7:08
SEP	4, 2025	9:53
AUG	3, 2025	8:36
JUL	2, 2025	10:21
JUN	4, 2025	4:46
MAY	1, 2025	5:01
APR	3, 2025	4:36
MAR	31, 2025	11:44
DEC	2, 2024	18:36
NOV	2, 2024	5:58
OCT	1, 2024	19:56
SEP	1, 2024	5:57

FIRST 0.10 GAL/HR PASS
EACH MONTH:

AUG	14, 2024	4:44
FEB	13, 2024	0:29
AUG	14, 2023	9:44
FEB	12, 2023	0:00
AUG	13, 2022	7:49

* * * * * END * * * * *