

03/05/25 5:43 PM

BEST STOP MARATHON
7269 BROADWAY
MERRILLVILLE, IN
219-736-4607

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 4: DIESEL

REPORT TYPE = LAST GROSS
DATE/TIME = 03/05/25 17:11
METHOD = SLD Gross Test
AVG. VOLUME = 1803
% VOLUME = 36.3

REPORT TYPE = LAST PERIODIC
DATE/TIME = 03/05/25 17:26
METHOD = CSLD Periodic Test
HOURS = 45
AVG. VOLUME = 1605
% VOLUME = 32.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/05/25 17:26
METHOD = CSLD Periodic Test
HOURS = 45
AVG. VOLUME = 1605
% VOLUME = 32.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/13/25 9:51
METHOD = CSLD Periodic Test
HOURS = 51
AVG. VOLUME = 1663
% VOLUME = 33.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/19/25 21:23
METHOD = CSLD Periodic Test
HOURS = 57
AVG. VOLUME = 1663
% VOLUME = 33.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/12/24 17:48
METHOD = CSLD Periodic Test
HOURS = 42
AVG. VOLUME = 1974
% VOLUME = 39.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/21/24 22:31
METHOD = CSLD Periodic Test
HOURS = 52
AVG. VOLUME = 1825
% VOLUME = 36.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/30/24 17:52
METHOD = CSLD Periodic Test
HOURS = 69
AVG. VOLUME = 1676
% VOLUME = 33.7

R DIC

03/05/25 5:42 PM

BEST STOP MARATHON
7269 BROADWAY
MERRILLVILLE, IN
219-736-4607

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 3: E85

REPORT TYPE = LAST GROSS
DATE/TIME = 03/05/25 17:02
METHOD = SLD Gross Test
AVG. VOLUME = 3409
% VOLUME = 68.6

REPORT TYPE = LAST PERIODIC
DATE/TIME = 03/05/25 14:53
METHOD = CSLD Periodic Test
HOURS = 46
AVG. VOLUME = 3211
% VOLUME = 64.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/03/25 23:25
METHOD = CSLD Periodic Test
HOURS = 48
AVG. VOLUME = 3248
% VOLUME = 65.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/20/25 17:00
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 3040
% VOLUME = 61.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/31/25 23:23
METHOD = CSLD Periodic Test
HOURS = 35
AVG. VOLUME = 2509
% VOLUME = 50.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/16/24 1:29
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 2959
% VOLUME = 59.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/19/24 17:23
METHOD = CSLD Periodic Test
HOURS = 51
AVG. VOLUME = 3434
% VOLUME = 69.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/28/24 10:25
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 3220
% VOLUME = 64.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/10/24 6:40
METHOD = CSLD Periodic Test
HOURS = 47
AVG. VOLUME = 2932
% VOLUME = 59.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/13/24 12:10
METHOD = CSLD Periodic Test
HOURS = 34
AVG. VOLUME = 3434
% VOLUME = 69.1

03/05/25 5:42 PM

BEST STOP MARATHON
7269 BROADWAY
MERRILLVILLE, IN
219-736-4607

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 2: PREMIUM

REPORT TYPE = LAST GROSS
DATE/TIME = 03/05/25 16:55
METHOD = SLD Gross Test
AVG. VOLUME = 856
% VOLUME = 17.2

REPORT TYPE = LAST PERIODIC
DATE/TIME = 03/05/25 17:37
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 1301
% VOLUME = 26.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/02/25 10:48
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 1582
% VOLUME = 31.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/15/25 23:53
METHOD = CSLD Periodic Test
HOURS = 38
AVG. VOLUME = 2069
% VOLUME = 41.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/20/25 1:12
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 2025
% VOLUME = 40.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/05/24 7:49
METHOD = CSLD Periodic Test
HOURS = 32
AVG. VOLUME = 1674

03/05/25 5:41 PM

BEST STOP MARATHON
7269 BROADWAY
MERRILLVILLE, IN
219-736-4607

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: UNLEADED

REPORT TYPE = LAST GROSS
DATE/TIME = 03/05/25 5:57
METHOD = SLD Gross Test
AVG. VOLUME = 3624
% VOLUME = 18.2

REPORT TYPE = LAST PERIODIC
DATE/TIME = 03/05/25 6:36
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 9049
% VOLUME = 45.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/01/25 3:19
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 10156
% VOLUME = 50.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/09/25 1:11
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 10452
% VOLUME = 52.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/21/25 1:54
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 9565
% VOLUME = 47.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/06/24 2:05
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 10004
% VOLUME = 50.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/18/24 0:32
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 10827
% VOLUME = 54.3

03/05/25 5:40 PM

BEST STOP MARATHON
7269 BROADWAY
MERRILLVILLE, IN
219-736-4607

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: UNLEADED

Gross Test
Prev 24 Hours 124
Since Midnight 92

Last Gross 03/05/25 5:40 PM
Last Periodic 03/05/25 12:52 AM
First Periodic 03/02/25 1:47 AM

Ln 2: PREMIUM

Gross Test
Prev 24 Hours 10
Since Midnight 6

Last Gross 03/05/25 4:09 PM
Last Periodic 03/02/25 6:45 PM
First Periodic 03/02/25 6:45 PM

Ln 3: E85

Gross Test
Prev 24 Hours 8
Since Midnight 6

Last Gross 03/05/25 3:13 PM
Last Periodic 03/04/25 8:58 AM
First Periodic 03/04/25 8:58 AM

Ln 4: DIESEL

Gross Test
Prev 24 Hours 1
Since Midnight 1

Last Gross 03/05/25 2:21 PM

03/05/25 5:40 PM

BEST STOP MARATHON
7269 BROADWAY
MERRILLVILLE, IN
219-736-4607

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: UNLEADED

Gross Test
Prev 24 Hours 124
Since Midnight 92

Last Gross 03/05/25 5:40 PM
Last Periodic 03/05/25 12:52 AM
First Periodic 03/02/25 1:47 AM

Ln 2: PREMIUM

Gross Test
Prev 24 Hours 10
Since Midnight 6

Last Gross 03/05/25 4:09 PM
Last Periodic 03/02/25 6:45 PM
First Periodic 03/02/25 6:45 PM

Ln 3: E85

Gross Test
Prev 24 Hours 8
Since Midnight 6

Last Gross 03/05/25 3:13 PM
Last Periodic 03/04/25 8:58 AM
First Periodic 03/04/25 8:58 AM

Ln 4: DIESEL

Gross Test
Prev 24 Hours 1
Since Midnight 1

Last Gross 03/05/25 2:21 PM

03/05/25 5:40 PM

BEST STOP MARATHON
7269 BROADWAY
MERRILLVILLE, IN
219-736-4607

Sensor Status Report -
All Sensors

#	Sensor Location	Status
L 1	UNLEADED STP	NORMAL
L 2	PREMIUM STP	NORMAL
L 3	E85	NORMAL
L 4	DIESEL STP	NORMAL
L 5	UNLD INTERSTICE	NORMAL
C 1	DIESEL INTERSTIC	NORMAL