

06/10/25 3:12 PM

BEST STOP MARATHON
7269 BROADWAY
MERRILLVILLE, IN
219-736-4607

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: UNLEADED

Gross Test
Prev 24 Hours 145
Since Midnight 83

Last Gross
Last Periodic 06/10/25 3:09 PM
06/10/25 1:46 AM
First Periodic 06/03/25 1:01 AM

Ln 2: PREMIUM

Gross Test
Prev 24 Hours 27
Since Midnight 21

Last Gross
Last Periodic 06/10/25 3:11 PM
06/08/25 12:22 PM
First Periodic 06/08/25 12:22 PM

Ln 3: E85

Gross Test
Prev 24 Hours 6
Since Midnight 1

Last Gross
06/10/25 8:15 AM

Ln 4: DIESEL

Gross Test
Prev 24 Hours 4
Since Midnight 2

Last Gross
Last Periodic 06/10/25 2:46 PM
06/10/25 9:38 AM
First Periodic 06/04/25 9:44 AM

06/10/25 3:13 PM

BEST STOP MARATHON
7269 BROADWAY
MERRILLVILLE, IN
219-736-4607

Sensor Status Report -
All Sensors

#	Sensor Location	Status
L 1	UNLEADED STP	NORMAL
L 2	PREMIUM STP	NORMAL
L 3	E85	NORMAL
L 4	DIESEL STP	NORMAL
L 5	UNLD INTERSTICE	NORMAL
C 1	DIESEL INTERSTIC	NORMAL

06/10/25 3:13 PM

BEST STOP MARATHON
7269 BROADWAY
MERRILLVILLE, IN
219-736-4607

TANK LEAK TEST HISTORY -
PASSED TEST RESULTS

T 1: UNLEADED

REPORT TYPE = LAST GROSS
DATE/TIME = 06/10/25 5:06
METHOD = SLD Gross Test
AVG. VOLUME = 6739
% VOLUME = 33.8

REPORT TYPE = LAST PERIODIC
DATE/TIME = 06/10/25 5:42
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 8391
% VOLUME = 42.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/07/25 3:54
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 9124
% VOLUME = 45.7

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/28/25 5:58
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 9530
% VOLUME = 47.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/04/25 23:41
METHOD = CSLD Periodic Test
HOURS = 31
AVG. VOLUME = 9542
% VOLUME = 47.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/15/25 3:02
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 10562
% VOLUME = 52.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/09/25 1:11
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 10452
% VOLUME = 52.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/21/25 1:54
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 9565
% VOLUME = 47.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 12/06/24 2:05
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 10004
% VOLUME = 50.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 11/18/24 0:32
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 10827
% VOLUME = 54.3

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 10/14/24 5:26
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 11400
% VOLUME = 57.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 09/13/24 2:54
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 11874
% VOLUME = 59.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/31/24 4:59
METHOD = CSLD Periodic Test
HOURS = 28
AVG. VOLUME = 10983
% VOLUME = 55.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/04/24 4:21
METHOD = CSLD Periodic Test
HOURS = 27
AVG. VOLUME = 8780
% VOLUME = 44.0

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/01/24 5:12
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 9994
% VOLUME = 50.1

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/29/24 5:19
METHOD = CSLD Periodic Test
HOURS = 30
AVG. VOLUME = 10024
% VOLUME = 50.2

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/01/24 1:55
METHOD = CSLD Periodic Test
HOURS = 29
AVG. VOLUME = 11197
% VOLUME = 56.1