



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 3/27/25

LEAK DETECTOR TEST (DATA SHEET)

Test Location Information

Name	FID 50029
Address	7269 Broadway
City	Merrillville, IN 46410
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg	Fe Petro ELLD		
Prem	Fe Petro ELLD		
E-85	Fe Petro ELLD		
Diesel	Fe Petro ELLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular	36	35	500 ml	189ml	2 cycles	Pass 
2	Premium	37	35	530 ml	189ml	2 cycles	Pass 
3	E-85	34	33	530 ml	189ml	2 cycles	Pass 
4	Diesel	33	33	550 ml	189ml	2 cycles	Pass 
5					189ml	.	
6					189ml	.	
7					189ml	.	
8					189ml	.	

Comment:

Technician Signature :

