

CITGO
302 JOLIET
CROWN POINT IN

JUL 6, 2025 16:25

CSLD TEST RESULTS

- - - - -

JUL 6, 2025 16:25

T 1:REGULAR NORTH
PROBE SERIAL NUM 544620

0.2 GAL/HR TEST
PER: JUL 6, 2025 PASS

T 2:REGULAR SOUTH
PROBE SERIAL NUM 544623

0.2 GAL/HR TEST
PER: JUL 6, 2025 PASS

T 3:PREMIUM
PROBE SERIAL NUM 041566

0.2 GAL/HR TEST
PER: JUL 6, 2025 PASS

T 4:DIESEL
PROBE SERIAL NUM 813759

0.2 GAL/HR TEST
PER: JUL 6, 2025 PASS

* * * * * END * * * * *

CITGO
302 JOLIET
CROWN POINT IN

JUL 6, 2025 16:25

LIQUID STATUS

- - - - -

JUL 6, 2025 16:25

NONE

* * * * * END * * * * *