



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date

4/3/25

HYDROSTATIC SPILL BUCKET INTEGRITY TEST

SINGLE- AND DOUBLE-WALLED VACUUM TEST METHOD

Facility Name:	Citgo	Owner:	Neeru Inc.
Address:	302 W Joliet St	Address:	302 W Joliet St
City, State, Zip Code:	Crown Point, IN 46307	City, State, Zip Code:	Crown Point, IN 46307
Facility I.D. #:	9578	Phone #:	

This procedure is to test the leak integrity of single- and double-walled spill buckets. See PEI/RP1200 Section 6.2 for hydrostatic test method, Section 6.3 for single-walled vacuum test method and Section 6.4 for double-walled vacuum test method.

Tank Number	1	2	3	4		
Product Stored	Regular N	Regular S	Premium	Diesel		
Spill Bucket Capacity	5 gal	5 gal	5 gal	5 gal		
Manufacturer	EBW	EBW	EBW	EBW		
Construction	SW	SW	SW	SW		
Test Type	Hydrostatic	Hydrostatic	Hydrostatic	Hydrostatic		
Spill Bucket Type	Product	Product	Product	Product		
Liquid and debris removed from spill bucket?	Yes	Yes	Yes	Yes		
Visual Inspection (No cracks, loose parts or separation of the bucket from the fill pipe.)	Pass	Pass	Pass	Pass		
Tank riser cap included in test?	Yes	Yes	Yes	Yes		
Drain valve included in test?	Yes	Yes	Yes	Yes		
Starting Level	10.5"	9"	9"	10.5"		
Test Start Time	1:40pm	1:45pm	1:50pm	2:00pm		
Ending Level	10.5"	9"	9"	5.5"		
Test End Time	2:40pm	2:45pm	2:50pm	3:00pm		
Test Period	1 Hr	1 Hr	1 Hr	1 Hr		
Level Change	0	0	0	-5"		
Pass/fail criteria: Must pass visual inspection. Hydrostatic: Water level drop of less than 1/8 inch; Vacuum single-walled only: Maintain at least 26 inches water column; Vacuum double-walled: maintain at least 12 inches water column						
Test Results	Pass	Pass	Pass	Fail		

Comments:

Tester's Name : Josh Rider

Tester's Signature : 