

CITGO
302 JOLIET
CROWN POINT IN

SEP 10, 2025 17:49

CSLD TEST RESULTS

SEP 10, 2025 17:49

T 1:REGULAR NORTH
PROBE SERIAL NUM 544620

0.2 GAL/HR TEST
PER: SEP 10, 2025 PASS

T 2:REGULAR SOUTH
PROBE SERIAL NUM 544623

0.2 GAL/HR TEST
PER: SEP 10, 2025 PASS

T 3:PREMIUM
PROBE SERIAL NUM 041566

0.2 GAL/HR TEST
PER: SEP 10, 2025 PASS

T 4:DIESEL
PROBE SERIAL NUM 813759

0.2 GAL/HR TEST
PER: SEP 10, 2025 PASS

* * * * * END * * * * *

CITGO
302 JOLIET
CROWN POINT IN

SEP 10, 2025 17:49

LIQUID STATUS

SEP 10, 2025 17:49

NONE

* * * * * END * * * * *