



 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

5296 Breakers Way, Carmel, IN 46033

Date

4/3/25

PRODUCT LINE TEST

Test Location Information

Name	FID 9578
Address	302 W Joliet St
City	Crown Point
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

Applied Pressure

50 psi

#1 Product Type : Regular

TIME	DATA	+/-	GPL	RES	GPH
12:35pm	62	0	0.0037	0	0
12:50pm	59	-3	0.0037	.0111	.0444
1:05pm	57	-2	0.0037	.0074	.0296
1:20pm	55	-2	0.0037	.0074	.0296
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : Pass



#2 Product Type : Premium

TIME	DATA	+/-	GPL	RES	GPH
1:40pm	77	0	0.0037	0	0
1:55pm	76	-1	0.0037	.0037	.0148
2:10pm	76	0	0.0037	0	0
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : Pass



#3 Product Type : Diesel

TIME	DATA	+/-	GPL	RES	GPH
2:25pm	63	0	0.0037	0	0
2:40pm	62	-1	0.0037	.0037	.0148
2:55pm	61	-1	0.0037	.0037	.0148
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : Pass



#4 Product Type :

TIME	DATA	+/-	GPL	RES	GPH
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		

Final Result : .





5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 4/3/25

PRODUCT LINE TEST

Test Location Information	
Name	FID 9578
Address	302 W Joliet St
City	Crown Point
Phone	
Contact	

Technician Information	
Name	Josh Rider
Cert #	UC202406986

Applied Pressure
50 psi

FINAL REPORT

SR. No.	Product Type	Result
1	Regular	Pass
2	Premium	Pass
3	Diesel	Pass
4		.
5		.
6		.

Both regular lines must connect because of the way they are used at this site.
Regular north was the only line that had working ball valve. Used silver bullet on other three

Comment :

Tester's Name : Josh Rider

Tester's Signature : 