

SMART STOP 1
302 W. JOLIET ST.
CROWN POINT, IN 46307
SITE # 00001

3/5/2025 18:13
LEAK ESTIMATE REPORT

TANK NO. 1 GAL

UNLEADED REG

THRESHOLD 0.20 GAL/HR
CONFIDENCE LEVEL 99.0%
PERCENT CAPACITY 37.60
GROSS 3579.3 GAL
NET 3618.9 GAL
LEVEL 37.343 IN
TEMP 44.195 F
WATER VOL 0.0 GAL
WATER LEVEL 0.000 IN
EST TIME 2 HRS 30 MIN

SMART STOP 1
302 W. JOLIET ST.
CROWN POINT, IN 46307
SITE # 00001

3/5/2025 18:14
LEAK ESTIMATE REPORT

TANK NO. 2 GAL

UNLEADED REG

THRESHOLD 0.20 GAL/HR
CONFIDENCE LEVEL 99.0%
PERCENT CAPACITY 32.69
GROSS 1879.8 GAL
NET 1899.6 GAL
LEVEL 34.122 IN
TEMP 44.955 F
WATER VOL 0.0 GAL
WATER LEVEL 0.010 IN
EST TIME 1 HRS 30 MIN

SMART STOP 1
302 W. JOLIET ST.
CROWN POINT, IN 46307
SITE # 00001

3/5/2025 18:14
LEAK ESTIMATE REPORT

TANK NO. 3 GAL

UNLEADED SUP

THRESHOLD 0.20 GAL/HR
CONFIDENCE LEVEL 99.0%
PERCENT CAPACITY 42.39
GROSS 1700.2 GAL
NET 1716.1 GAL
LEVEL 28.168 IN
TEMP 44.931 F
WATER VOL 0.0 GAL
WATER LEVEL 0.000 IN
EST TIME 1 HRS 30 MIN

SMART STOP 1
302 W. JOLIET ST.
CROWN POINT, IN 46307
SITE # 00001

3/5/2025 18:15
LEAK ESTIMATE REPORT

TANK NO. 4 GAL

DIESEL

THRESHOLD 0.20 GAL/HR
CONFIDENCE LEVEL 99.0%
PERCENT CAPACITY 56.99
GROSS 1700.1 GAL
NET 1721.1 GAL
LEVEL 35.532 IN
TEMP 44.400 F
WATER VOL 0.0 GAL
WATER LEVEL 0.520 IN
EST TIME 1 HRS 30 MIN