

30 DAYS WALK THROUGH INSPECTION

Tanks Data		Contact Number
UST Facility I.D. (FID) #	16295	Contact email
Facility Name	AMOC	Date of Inspection
Address	1643 Prairie Ave, South Bend	05-30-25
Operator on Duty Name	John V. 13	Name of the Person Conducting Inspection
Operator Training current		Operator Training
Operator Training current	Registration/Notification Form	Operator Notified
Is Registration current with correct owner, operator etc.	Release Detection	Operator Notified
Release Detection Method	ATG	Operator Notified
Make and Model	VR-TL5350	Operator Notified
Does it have paper?	Yes	Operator Notified
Is it in Alarm mode?	Yes	Operator Notified
Interstitial Monitoring Sensor Status Normal	Yes	Operator Notified
Necessary Monthly Printout Taken	Yes	Operator Notified
Spill Buckets		Operator Notified
Are Spill Buckets Clean and free from water, debris, product etc?	Yes	Operator Notified
Are the Spill Bucket in good condition and free of damage/cracks	Yes	Operator Notified
Is Fill pipe cap tight and fill pipe free from any obstruction?	Yes	Operator Notified
Are Sumps Clean and free from water, debris, product etc?	Yes	Operator Notified
Under Dispenser Containments (UDC)	Yes	Operator Notified
Are UDCs clean and free from water, debris, product etc?	Yes	Operator Notified

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name: _____ Signature: _____ Date: _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com 20220516