

PL EXPO 4
1643 PRAIRIE AVE
SOUTH BEND, IN 46613

APR 26, 2025 5:54 PM

LEAK TEST REPORT

T 1:UNL
PROBE SERIAL NUM 225703

NO TEST DATA AVAILABLE

***** END *****

PL EXPO 4
1643 PRAIRIE AVE
SOUTH BEND, IN 46613

APR 26, 2025 5:54 PM

CSLD TEST RESULTS

APR 26, 2025 5:54 PM

T 1:UNL
PROBE SERIAL NUM 225703

0.2 GAL/HR TEST
PER: APR 26, 2025 PASS

T 2:PREM
PROBE SERIAL NUM 128151

0.2 GAL/HR TEST
PER: APR 26, 2025 PASS

***** END *****

PL EXPO 4
1643 PRAIRIE AVE
SOUTH BEND, IN 46613

APR 26, 2025 5:54 PM

LEAK TEST REPORT

T 2:PREM
PROBE SERIAL NUM 128151

NO TEST DATA AVAILABLE

***** END *****

PL EXPO 4
1643 PRAIRIE AVE
SOUTH BEND, IN 46613

APR 26, 2025 5:54 PM

LIQUID STATUS

APR 26, 2025 5:54 PM

L 1:UNL STP
SENSOR NORMAL

L 2:PREM STP
SENSOR NORMAL

L 3:INT
LIQUID WARNING

***** END *****